



**SECTION VIEW**

Supply line may enter trough from above ground or through tank floor. For above ground installation, protect the pipe from livestock and/or cold weather damage. Maximum diameter of supply line shall be 1 inch. All pipe and fittings shall be schedule 40 galvanized metal.

DIMENSIONS

D = \_\_\_\_\_ ft  
 L = \_\_\_\_\_ ft  
 H = \_\_\_\_\_ ft  
 \_\_\_\_\_ gallons

Drawing not to scale. Standardized drawings must be adapted to the specific site.

<b>U.S.D.A. NATURAL RESOURCES CONSERVATION SERVICE</b>	JOB CLASS	Date
	CAD FILE NO. LSK-0154.DWG	Designed _____
	SHEET OF	Drawn _____
		Checked _____
	Approved _____	