



Optional Backwall and Curb
 Yes No

- NOTES:
- a. Section B-B is on Sheet 2.
 - b. Notes are on Sheet 3.
 - c. At contractor's option a construction joint as shown below may be installed. As approved by NRCS equivalent construction joints may be used.
 - d. Steel plate for construction joints to be lapped 3 inches and bolted with minimum of 2-3/8 inch galvanized bolts with nuts and flat washers.

Date	
Designed	
Drawn	
Checked	
Approved	

ROOFED STACKING STRUCTURE
SOLID MANURE



DRAFT
NOT FOR
CONSTRUCTION

File Name	
Drawing Name	29-N-651
Sheet	of