


**ELEVATION VIEW**




**SINGLE GATE**

**NOTES:**

1. Concrete shall be 3000 psi average compressive strength. Concrete for line posts to be 9 inch minimum diameter. Concrete for all other posts to be 12 inch minimum diameter, unless noted. Fabric shall not be attached to posts until the concrete has cured for at least 5 days.
2. All posts are 7'-6" minimum length.
3. For all concrete around posts, extend concrete 2 inches above grade and trowel to a crown to shed water.
4. Line posts may be drive set a minimum of 42 inches into grade and concrete omitted, with post length 8'-6" minimum.
5. End, corner, or gate posts shall be set at the beginning and end of each continuous length of fence and at abrupt changes in vertical or horizontal alignment.
6. Pull posts shall be used in all straight spans of fence longer than 500 feet.
7. All posts shall be installed vertically. Where post are installed on inclined surface, the angle of the post shall be adjusted so that the post will be vertical.
8. Posts, gate frames, braces, rails, stretcher bars, truss rods and tension wire shall be of steel, zinc coated by the hot dipped method.
9. The fencing shall be #9 gauge fence fabric, standard 2-inch chain link diamond mesh, zinc or aluminum coated steel, aluminum alloy or vinyl coated steel.
10. Chain link fabric shall be placed on the side of the line post closest to the location of livestock.
11. Stretcher bar shall be at least 3/16"x 3/4" and not less than 2 inches shorter than the normal height of the chain link fabric.
12. Top rail shall be in lengths not less than 18 feet and shall be fitted with couplings or swaged for connecting the lengths into a continuous run. The couplings shall be not less than 6 inches long and shall allow for expansion and contraction of the rail.
13. Materials and workmanship not shown on this drawing shall conform to the manufacturer's specifications.
14. This drawing requires supporting documentation prior to use and must be adapted to specific site.


Scale: 3/8" = 1'-0"

Date		Designed		Checked	
	8/13		M. QUINONES		
		Drawn		Approved	
5 FOOT CHAIN LINK FENCE					
<b>NRCs</b> Natural Resources Conservation Service United States Department of Agriculture					
File No. IL-ENG-71					
Drawing No.					
Page 1 of 2					
Sheet of					



**GATE POST**  
Scale: 1 1/2" = 1'-0"

**END POST  
PULL POST  
CORNER POST**  
Scale: 1 1/2" = 1'-0"



**DOUBLE GATE**  
Scale: 3/8" = 1'-0"

Date	8/13
Designed	M. QUINONES
Drawn	
Checked	
Approved	

**5 FOOT CHAIN LINK FENCE**



File No.	IL-ENG-71
Drawing No.	
Page	2 of 2
Sheet	of

Scale AS Shown