

Appendix C

North Central Missouri Regional Water Source Evaluation

Northcentral Missouri Regional Water Source Evaluation

for the counties of

Adair, Chariton, Grundy, Linn, Livingston,
Macon, Mercer, Putnam, Schuyler, and Sullivan

November 2016

Aaron S. Jones, PE

Cary D. Sayre, PE

John Holmes, PE

Produced with support from Olsson Associates



Table of Contents

Preface	1
Introduction to Region and Water Suppliers	3
History of Water in Rural North-central Missouri.....	4
Overview of Surface Water Cluster Evaluations	8
RESOP Method.....	8
7 Q10 Method.....	10
Surface Water Cluster Reports SW-1 to SW-6.....	11
Summary of Surface Water Cluster Evaluations.....	36
Overview of Groundwater Cluster Evaluations	37
Groundwater Cluster Reports GW-1 to GW-9	40
Summary of Ground Water Cluster Evaluations	71
Overview of Out-of-Region Cluster Evaluations	73
Out-of-Region Reports OR-1 to OR-3	74
Summary of Out-of-Region Cluster Evaluations	80
Summary of Findings	81
Conclusion	86
Bibliography	87
Appendicies	89

Preface

The goal of the following analysis is to determine the ability for existing drinking water source(s) to provide sufficient, dependable raw water for the 10-county region of north-central Missouri. By grouping Public Water Systems (PWS's) utilizing the same raw water source(s), into clusters, the regional availability of water can be displayed more accurately. The 18 clusters are split into 3 groups for analysis: groundwater, surface water, and out-of-region clusters. These groupings are detailed below. This approach allows planners to identify instances when a supply source in one cluster has excess capacity during the drought of record (DOR) and another cluster has deficient supply. The first step is understanding the local need for water and identifying whether that need is being met. The second step is evaluating whether those systems with adequate water supply are capable of providing those with inadequate water supply. For the purposes of this evaluation the focus will remain on the first step.

The analysis to determine adequacy of a water source to serve a cluster is based on the following assumptions:


- Current daily raw water demands remain constant
- DOR recharge conditions
- Fifty years of sediment loading for surface water systems
- Water sources are sized according to current Missouri Dept. of Natural Resources design requirements
- Geologic and hydrogeological evidence
- Local history and information specific to water supply

Based on these assumptions, if a source is unable to supply the current daily demand, the cluster will be labeled as an inadequate source. Conversely, if a source is able to supply the current daily demand the cluster will be labeled as adequate.

This study was conducted using information from U.S. Geological Survey (USGS), Missouri Department of Natural Resources (MDNR), individual system interview data and the U.S. Department of Agriculture- National Resource Conservation Service (NRCS).

Staff from the engineering firms of Allstate Consultants and Olsson Associates collaborated on the production of this document. For more information, contact Aaron S. Jones, PE at ajones@allstateconsultants.net or Chad Johnson, PE at cjohnson@olssonassociates.com.

Cluster ID	PWS Providing Water for Cluster
SW-1	North Central Missouri Regional Water Commission
SW-2	City of Brookfield & City Marceline
SW-3	City of Unionville
SW-4	Trenton Municipal Utilities
SW-5	City of Kirksville
SW-6	Macon Municipal Utilities
GW-1	City of Keytesville
GW-2	MO American Brunswick
GW-3	Chillicothe Municipal Utilities
GW-4	Livingston County PWSD #2
GW-5	Linn County Consolidated PWSD #1
GW-6	Linn-Livingston PWSD #3
GW-7	City of Meadville
GW-8	City of Princeton
GW-9	City of Salisbury
OR-1	Rathbun Regional Water Association (surface water)
OR-2	Clarence Cannon Wholesale Water Commission (surface water)
OR-3	Livingston County PWSD #4 (groundwater)



QGIS Version: 2.14.5-Essen Path: //Allstate/GIS Data/CARES/Quantum Projects/Missouri Water Supply 2.8nof.qgs

Figure 1: Location Map for Region of Study.

Introduction to Region and Water Suppliers

The 10-county region of north-central Missouri includes the following counties: Adair, Chariton, Grundy, Linn, Livingston, Macon, Mercer, Putnam, Schuyler, and Sullivan. The residents and businesses of these counties are dependent upon the 19 water suppliers, within 18 clusters, to provide treated water daily. Figure 1, above, displays the region and communities within it.

Each cluster has a primary PWS that treats water from the source(s) and then transmits the treated water to other public water systems within the cluster. In some instances, a single PWS may be a part of two or more clusters. This is because the water system has multiple isolated systems for which the water is purchased from different providers. Note that Cluster SW-2 has two PWS's (City of Brookfield and City of Marcelline) supplying individually treated water from different sources within the cluster. In this case, there is some interconnection between suppliers.

Generally speaking, the infrastructure needed to transport meaningful amounts of water between clusters is non-existent and development of the infrastructure is not viable for the limited amount of excess capacity that may exist within pockets in the region. The inability of current infrastructure to transport large volumes between adjacent systems, across cluster boundaries, is because of the original sizing of water mains and hydraulics. The existing water mains were sized by engineers based on maintaining adequate flow, water quality standards, and minimum pressures for individual systems.

There are six surface water clusters (SW-1-through SW-6), nine groundwater clusters (GW-1-through GW-9) and three out-of-region clusters (OR-1-through OR-3) that provide finished water in the 10 county region in North Missouri. In Figure 2, below, each segment of the pie corresponds to a producer supplying treated water within the 10 county region. The size of each segment is proportionate to the average daily demand produced by each system. A total of 13.723 million gallons per day (MGD) of treated water was produced in 2015, according to data provided by PWS's. This treated water demand data, is referenced through this evaluation. This graphic brings understanding to how regionalized the study region has become.




Figure 2: Regional Source Water Clusters by Type and Percent Production

History of Water in Rural North Central Missouri

Water is not a new product or commodity, but the way it is accessed for consumption has change dramatically, in rural north central Missouri. Similarly, the impact of indoor potable water on the United States has been so profound the United States government included questions pertaining to residential plumbing facilities in decennial US Census Housing data, collected from 1940 to 1990 (U.S. Census 2016). Figure 3, below, reveals how rapid the evolution of residential plumbing occurred. The left axis depicts the percentage of residences lacking complete plumbing facilities. Although the intent of the graph is to show data for Missouri, the entire US is included for reference. Coupled with the number of Missouri residences with complete plumbing facilities, the graph captures not only the number of homes modified but also new construction residences with plumbing during a given period. The data shows that over 900,000 homes were built or modified to include complete plumbing facilities between 1950 and 1970. Complete plumbing facilities are defined as hot and cold piped water, a bath- tub or shower, and a flush toilet. (U.S. Census 2016)




Figure 3: Plumbing Facilities in Missouri and US from U.S. Census data 1940-1990. (U.S. Census Bureau 2016)

The indoor plumbing trend was not exclusive to urban residents, many small rural communities provided available water to residents near town when possible. Many rural homes operated cisterns and had a pump and pressure tank that was utilized to force water into the home's bathroom and kitchen. At that time homes did not have automatic dishwashers and automatic clothes washers, as a general rule, as they used too much water and they would run the cistern dry. Families typically used a bathtub full of water for multiple family members for bathing and residential bathroom showers were a rare thing. When the water level in the cistern became depleted, pumps located in cellars or a home basement would lose prime. Periodically, the homeowner would

clean the cistern and dump bleach in it. Impurities in the cistern would enter the cistern from barn roof gutter drains, house roof gutter drains, surface water conduits, and pond water being pumped in to the cistern. Items that might be cleaned from a cistern could include silt; bird feces; bird feathers; dead animals such as rabbits, rats, cats, birds, snakes, etc.; algae from the ponds; grass clippings; and other such items. Farmers were constantly cleaning out bird nests from gutters and down spouts to keep impurities out of the home's water supply. Some of the better cistern set ups included roof gutter drains dumping into barrels or cylinders filled full of sand that would provide some filtering prior to entering the cistern.

Prior to rural water districts expansions in the late 1960's, residential water in north central Missouri was limited to cisterns and shallow wells. Many of the old cisterns and residential wells were located for ease of access which was typically as close to the home and barn as possible. Many of the old hand dug wells and cisterns have been abandoned and/or collapsed. Remnants of the old cisterns and hand dug wells with windmills can still be seen scattered across north Missouri but many of the old windmills have been torn down.

Surface runoff and livestock waste above and around the well or cistern allowed surface water to enter the water supply. Water quality testing performed by agencies such as University of Missouri Extension, Missouri Department of Health, MDNR, and USDA-NRCS concluded that many of the shallow wells and cisterns were high in nitrates. Elevated nitrate levels utilized for human and livestock water posed health risks such as Blue Baby Syndrome, stillborn calves and stillborn pigs. This water quality testing further increased the need and desire for safe potable water systems to be provided to rural areas (Sievers and Fulhage 1992).

"Groundwater contamination is possible, and numerous cases of groundwater pollution have been documented. However, most are local problems caused by private septic systems, agricultural runoff from livestock confinements, fertilizer, and other agricultural chemicals, such as, pesticides and herbicides" (Miller and Vandike 1997).

Rural water districts in Missouri started in the mid-1960's in the counties surrounding the urban areas of Kansas City and St. Louis. Districts began when people formed steering committees and groups to push for rural water. These systems would allow the rural residents to discontinue using pond water, cistern water, and individual wells for drinking water purposes. The first rural water districts were formed prior to organized design criteria, with private funds by individuals wanting potable water; Plastic and poly vinyl chloride (PVC) pipe allowed the distribution system construction to be more economical than cast iron or ductile iron pipe.

The first rural water districts utilized small-diameter water mains ranging from 3/4-inch to 2 1/2 – inches to fill up cisterns with a yard hydrant. Design criteria for the sizing pipes for rural water systems was initially non-existent in the early to middle 1960's. PVC pipe allowed cheaper pipe to be installed, but many of the larger engineering companies would not specify or allow its use. Agencies such as the State of Missouri worked with Engineers and communities to develop PVC water pipe design criteria such as early glue joint pipe and now slip joint pipe. Engineers within the Missouri Department of Health (currently MDNR) reviewed plans and specifications for the PWS's and began researching the amount of rural water users compared with the gallons of water utilized. From this research and data, it was determined that a near straight line could be plotted on semi-log paper thus the formula for rural water systems was developed in about 1970:

$$Q = 12C^{0.515}$$

Where: Q = water demand in gallons per minute

C = number of residential users

This formula was utilized for years in hand calculations for rural water districts all over the state of Missouri and beyond. The formula calculates water supply for residential household use only and does not account for fire flows (MDNR 2013).

These new public entities (i.e. water districts) allowed people to pass bond issues to fund initial phases of the water district. The next expansion phases of the water district development required people to take on more debt to help out their neighbors in obtaining potable water from a rural water district. This was accomplished through funding by USDA- Rural Development (formerly USDA-FmHA), MDNR, and Community Development Block Grant (CDBG) as districts began to materialize by utilizing low-interest loans and grants. PVC pipe, pumping stations, and elevated finished water storage reservoirs began to be constructed in the rural areas as a pathway to successful rural water districts. This method of rural people helping out each other through the acceptance of debt allowed the rural water districts began to grow and expand.

In part, research from the University Extension indicated farmers' livestock utilizing safe potable water for livestock can result in greater livestock production and profit. Often times, utilizing the rural water district water supply was more dependable and required less maintenance than the farmers operating and maintaining their own wells, cisterns, pump and pressure tanks, pond float and pump system, or any other type of water supply system. Many farmers currently utilize rural water for at least a portion of their livestock watering needs.

Through time, the drinking water standards and criteria have become more stringent. Trihalomethanes, disinfection, turbidity, security and other such drinking water standards have caused many PWS's to consolidate with larger systems. The closure or consolidation of the 28 treatment facilities since 1980 is one of the most compelling data trends for rural water systems in the region. The complete listing with a summary of factors for closure, including both surface and groundwater sources, is found in Appendix C. Figure 4, below, depicts the location of the systems now purchasing water from an adjacent system after moving away from their own water source and closing their treatment plants. The aggregation of water systems, or development of unintended regional water supplies, to suppliers with larger capacity has impacted the ability of remaining sources to ensure adequate, reliable raw water for all customers. The impacts of unintended regional water supplies has not been sufficiently evaluated within the 10-county area. The analysis contained herein will evaluate existing water sources and evaluate the need for a regional solution for providing adequate, reliable water. In many cases throughout north Missouri, the raw water supply source capacity was not increased at the same order of magnitude that the drinking water demands increased through the addition of rural water expansion and consolidation.

The first example, the City of Bucklin's lake was constructed in the mid-1930's to be a raw water supply reservoir for the City and to fill steam engines for the adjacent railroad. Bucklin began selling treated water to the local rural water district during the early 1980's. The reservoir silted in through the years and the more current U.S. Environmental Protection Agency's (EPA) drinking water standards became too stringent for the City to comply without a tremendous cost. The City of Bucklin closed their water plant in 2010, no longer sell water to the water district, and now both the city and rural users obtain their water from the City of Marceline via Chariton-Linn PWSD #3. This consolidation created additional strain on City of Marceline's water supply system, from raw water source availability, to the treatment, operation, and maintenance capacities.

The second example references the letter in Appendix B, shows an example of a supply system, Linn County Consolidated PWSD #1, in search of another well site after their existing well had been influenced by high iron. The drillers' letter states after 11 test wells that "We don't feel a suitable formation for a well to produce at least 50 GPM has been encountered." This was in an area adjacent to Locust Creek.

In summary, rural public water supplies and even indoor plumbing has only been prevalent in Missouri since around the 1950's. Originally, rural water suppliers were formed to improve health conditions. As those benefits were realized systems rapidly outgrew water source supply capacity. With the public dependent upon a single supply, a need for quality standards was introduced in the Safe Drinking Water Act. These standards became more than some communities could achieve or afford, so reliance upon adjacent supplies began. Figure 4, below, identifies the 28 closed systems in the region since 1980. In an area where source water is scarce, regionalization

has led to the current conditions of widespread dependency on a few sources. Only three of the 18 clusters provide water to their one district or community; the remainder provide wholesale water.




Figure 4: Closed Drinking Water Treatment Facilities in the 10 County Region, based on (MDNR- Baker)

Overview of Surface Water Cluster Evaluations

Water supply systems in north central Missouri rely on a variety of surface water sources, including in-stream reservoirs, off-stream reservoirs, and streamflows. Evaluation of these surface water sources, requires analysis of either the Reservoir Operation Study Computer Program (RESOP) for instream reservoirs, or the 7 day average low flow rate that occurs once in 10 years on average (7 Q10) of streamflows combined with capacities of off-stream reservoirs. These methods were analyzed against the available rain gauge data from this period, 1952-1959, as the DOR, which is the longest duration and most intense drought in Missouri on file.

RESOP Method

The MDNR approved method for instream reservoir analysis is the NRCS's RESOP, which is used to calculate "optimized demand" as described in NRCS Technical Release 19.

Optimize Demand -- indicates that the lowest storage will be checked against the lower limit and the demand modified until the maximum demand is reached and no deficiency occurs. (NRCS 1987)

To avoid confusion with the word demand, in this evaluation optimized demand will be referred to as reservoir yield capacity and defined as:

Reservoir Yield Capacity is the calculated volume of raw water that can be withdrawn daily from a reservoir to maintain a minimum volume in the reservoir to meet other purposes, and meet water source design guidelines.

The term Normal Demand will be defined as:

Normal Demand is the average daily quantity of water used by customers, based on an annual period.

The RESOP calculates the reservoir yield capacity by using initial volume, water supply volume, rainfall, runoff, and evaporation parameters. If daily water supply withdrawals (normal demand) are greater than reservoir yield, the results will be a shortage of water during a DOR. The evaluation contained herein will characterize system clusters with a normal demand greater than the calculated water source yield capacity, as an inadequate source. The system clusters with a normal demand less than its calculated yield capacity will be characterized as an adequate source.

Normal Demand (raw water) < Reservoir Yield Capacity Adequate Source

Normal Demand (raw water) > Reservoir Yield Capacity Inadequate Source

Some of the evaluated reservoirs serve multiple purposes such as recreational, drinking water supply, and flood control. In the case of a water supply and recreational use reservoir, a minimum volume, or lower limit, must be established to maintain aquatic habitat and recreational uses. Other examples of lower limit volumes include physical intake inlet elevations and water quality thresholds. Note that these limitations and thresholds are different for each source. These lower limits were not included in the Missouri Water Supply Study of 2013 (MDNR 2013), so that analysis assumes that quality drinking water can be withdrawn from the lake until the lake is dry. The Missouri Water Supply Study provided the background data and base RESOP models for this evaluation, but this new, more detailed analysis was completed to better quantify water availability in the 10-County region by accounting for added sediment over the next 50 years, and reasonable limits on acceptable lake levels.

Given the sensitivity and security of information regarding specific design details of public water supply inlet structures, systems interviewed asked for those details to be omitted from this evaluation. Some systems within the study region shared their inlet elevations and discussed which inlets were typically used. One system referenced water analysis conducted on the entire water column and noted water from the lowest inlet elevation was "oxygen deprived and therefore highly reactive during jar testing." By conducting routine jar testing the systems staff determined that they could use less chemical to treat water 4 to 6 feet below the water surface.

Water inlet elevations vary by source, as well as by water quality horizons. This evaluation could not reasonably consider all variables that affect each supply in the region and, therefore the assumption of the lower one-third reservoir elevation was made to account for inaccessible water and water quality limitations, and is based on the knowledge of systems within the study region. Note the one-third elevation, from the spillway to the lowest pool elevation, is not equal to one-third of the reservoir volume. Bathymetric evaluations by USGS from the Missouri Water Supply Study of 2013 were used for calculations.




Figure 5: Reservoir Cross section (not to scale)

When evaluating a source for quantity and reliability the Minimum Design Standards for Missouri Community Water Systems states the following in Chapter 3 Section 1.1a:

“Reservoir storage volume shall provide a reasonable surplus for reserve storage. A reasonable amount of surplus reserve storage should be considered in order to maintain public confidence in the reliability of supply at predicted depletion levels during a prolonged severe drought. A minimum of 120 days surplus reserve storage should be considered.”

This public confidence volume should be accounted for in the portion available for water supply, as shown in the Middle 1/3 elevation in Figure 5. This volume is calculated by multiplying the normal demand by 120 days. This quantity of million gallons must then be converted to acre-feet and added to the lower limit of RESOP analysis when calculating reservoir yield capacity. An example of the impact of public confidence is included in the following Cluster SW-5 report.

In order to provide a thorough investigation of the water supply dependability in the 10-county region, the RESOP analyses were updated for differing assumptions. RESOP input parameters for lake volumes were also modified for sediment to reflect the volume of reservoir capacity reduced by the accumulation of sediment over the next 50 years. Some of the RESOP graphs show this as adjustment for sediment, which is the reservoir levels assuming normal demand stays constant, but shifted to account for the reduced reservoir volume due to sedimentation over 50 years.

To accurately model extreme conditions the scenarios considered must reflect conditions when no pumping will be allowed. These no pumping conditions have been observed in actual pumping data sets. As an example the largest streamflow in the region is the Thompson River which provides water for Cluster SW-4. The USGS recorded the daily flows in the Thompson River observation station at Trenton, MO. The data shows a four consecutive-month period (November 1955 to February 1956) when average monthly flows (from daily flow calculations) in the Thompson River were below the base flow of 9 cfs, therefore no pumping could be allowed during this time. See Cluster Report SW-4 for more information. Through observed data and because other streamflows smaller than that of the Thompson River are used to supplement in-stream reservoirs, (which prohibited pumping during the DOR), the capacity from pumping will not be considered as a dependable source of water.

An important note about RESOP analysis is that unless the start of a DOR was accurately predicted and pumping was reduced prior to the beginning of the drought, in the case that normal demand exceeds reservoir yield, the

reservoir would not actually be able to produce the reservoir yield because it would be drawn down by the normal demand before conservation measures could be implemented. In other words, the normal demand needs to be below the reservoir yield, or the reservoir yield could not actually be achieved. So, in these cases, the reservoir yield overestimates the available water.

In the case when a PWS uses multiple reservoirs for raw water supply an additional calculation is needed to identify the proportion of total normal demand on each source. The proportional demand approach was used in this evaluation similar to the approach by MDNR in the Missouri Water Supply Study of 2013. This calculation was only used in Cluster SW-5 and detailed calculations are included in its report.

7 Q10 Method

For systems in the region that rely on streamflow, the Minimum Design Standards for Missouri Community Water Systems stipulates in Chapter 3 Section 1.1.f:

“When a river or stream is to be used as the sole source of water, the flow in the river or stream shall exceed the current registered and future downstream uses, instream flow recommendations, usually the 7 day Q 10 flow rate, and the design year future water system demand. Historical data must be used to determine that stream flows are adequate. Where the nearest gauging station is downstream of the intake site, a drainage area ratio or other approved method to represent the intake location must adjust the flow data. Data from an upstream station may be used. For streams where data does not cover the DOR, data from similar streams may be used to correlate or predict stream flows, with department approval” (MDNR 2013).

The 7Q10 is the 7 day average low flow rate that occurs once in 10 years on average. So, by definition, the flow in the stream during the DOR will be below the 7 day Q 10 flow rate. The 7 day Q 10 flow rate represents a moderate drought of the kind that occurs once in 10 years. This leaves no capacity for the water system to pump from the stream during any drought more severe than the 10 year return period drought.

In the north-central region of Missouri several systems use a combination of streamflow and reservoirs to provide water. An important step in evaluating the dependability of a source, is considering cases when augmenting (pumping) a source with water from streamflow is not an option. The Missouri Water Supply Study describes this circumstance in the following excerpt:


“Several of the examined water supply systems are from a collection of surface water sources, which can include several small lakes in series or tandem and often supplemented by in-stream diversion pumps. These analyses were made for some of the most critical supplies. Cities usually use two sources to supply their needs. These sources are lakes and flowing streams. Water stored in lakes comes from rainfall runoff to the lakes. Many of the lakes are too small in size and drainage area to satisfy local needs. As a result, the supply provided by the lakes must be supplemented by other sources. A common practice is to pump from streams into the lakes during high stream flows in an attempt to keep water levels in lakes near full. During droughts one can expect the streams to dry up or stream flow to be so low that pumping cannot be achieved” (MDNR 2013).

The following surface water cluster reports provide information on specific systems and sources within each of the six clusters, as well as the determination of a source to be adequate or inadequate.

Surface Water Cluster Reports SW-1 to SW-6

Cluster SW-1

Sources Inadequate



There are currently two lake sources for Cluster SW-1, operated by the North Central Missouri Regional Water Commission (NCRMWC) near Milan, Missouri. The cluster map above shows the service area for this cluster and the Production and Demand table on the next page details systems dependent upon these sources for all water supply needs. The demands listed are average daily treated water usage, based on an annual period. NCRMWC currently produces approximately 0.572 MGD of treated water and sells another 0.923 MGD raw water to Premium Standard Farms, which operates its own treatment facility for industrial purposes. The single treatment facility is designed to produce 2.4 MGD and enough land is owned by the NCRMWC to expand the facility to an ultimate approximate capacity of 6.5 MGD treated water.

Since 1985 four communities in this cluster have abandoned water treatment activities. Green City was mandated by the MDNR to cease treatment activities in 2004. The Inactive Sources table on the next page identifies those communities and briefly describes the reasoning for closure.

Assessing the two reservoir sources, Elmwood Lake and Milan Lake (Golf Course Lake), it is important to note that pumping from Locust Creek is necessary to maintain current demand. Both the 194-acre Elmwood Lake and 41 acre Milan Lake are supplemented with pumping from Locust Creek during normal and dry periods to maintain adequate levels. During wet periods pumping is conducted as needed. As both sources continue to decay and silt, the available source water capacity continues to decline. This reduction of capacity threatens health, safety, and economic sustainability of communities dependent upon this supply. Modeling conservative scenarios over the next 50 years, with siltation and drought of record conditions, RESOP analysis shows that the Elmwood Lake and Milan Lake, respectively, could daily yield 0.800 and .140 MGD of raw water. Cluster SW-1's total raw water yield capacity is 0.940 MGD, which is 0.744 MGD less than the average daily raw water demand under current conditions, therefore the sources for Cluster SW-1 are inadequate. USGS Low Flow data shows the 7Q10 is less than 0.24 MGD which means that the stream will be unable to provide sufficient flow in a DOR.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-1	North Central Missouri Regional Water Commission					1.572		n/a
	Green City						100%	0.122
	Green Castle						100%	0.034
	Milan						100%	0.180
	Sullivan County PWSD #1						100%	0.274
	Browning						100%	0.017
	Humphreys Newtown						100%	0.007 0.016
Premium Standard Farms (Raw Water Industrial Customer)						100%	0.923	


Inactive Sources Within Cluster						
System ID#	System Type	System Name	County	Source	Year of Closure	
MO2010329	Surface Water	Green City	Sullivan	Inadequate lakes to demand; single stage treatment facility became inadequate; closed plant; now purchase water from NCMRWC	2005	
MO2010574	Groundwater	Newtown	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1995	
MO2010389	Groundwater	Humphreys	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1990	
MO2010108	Groundwater	Browning	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1990	

Surface Water Supply(s) Within Cluster											
Cluster	Lake/ Reservoir	Cluster Current Demand		Raw Water Capacity Without Pumping, With Sediment		Excess Capacity (Reservoir Yield- Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
		Normal Treated (MGD)	Normal Raw (MGD)	Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
SW-1	Elmwood Reservoir	1.572	1.629	0.800	0.940	-0.689	S, R	1972	194.77	2503.2	2416.5
SW-1	Milan Lake (Golf Course)			0.140			S, R	1940	41.01	555.2	500.3

Results from USGS Low Flow Equations* for Stream Intakes in 10-county region									
Cluster	Supplier	PWS System ID	Intake	Inputs			Outputs		
				Drainage Area (MI ²)	Length (mi)	Stream Variable (MGD)	7Q10 (MGD)	30Q10 (MGD)	60Q10 (MGD)
SW-1	NCMRWC	2021537	Locust Creek at Intake	217.63	44.08	0.745	0.264	0.568	0.921


* Computed Statistics at Streamgages, and Methods for Estimated Low-Flow Frequency Statistics and Development of Regional Regression Equations for Estimating Low Flow Frequency Statistics at Ungaged Locations in Missouri, USGS 2013

Elmwood Lake with Low Limit of 87 AC-FT Storage from 1951 to 1959




RESOP Graph 1 Elmwood Lake

Golf Course Reservoir with Low Limit of 55 AC-FT Storage from 1951 to 1959



Cluster SW-2

Sources Inadequate



The two sources for Cluster SW-2 are the City of Brookfield (SW-2B) and the City of Marceline (SW-2M), both of which operate separate surface water reservoirs and separate water treatment facilities. These two communities and sources are included in Cluster SW-2 because of a common secondary system in Chariton-Linn PWSD #3. Marceline does not provide water to Brookfield, nor does Brookfield provide water to Marceline, but Chariton-Linn PWSD #3 is responsible for a large part of both sources demand. Of the 8 systems in this cluster that have abandoned treatment activities, 7 have been purchased by or purchase water from Chariton-Linn PWSD #3. These systems are noted on the Inactive Sources table in this section. The closure of these eight systems have caused demand to increase from both Brookfield and Marceline, causing a larger water deficit for these two larger communities during drought conditions.

The City of Brookfield maintains four ground storage basins, known as the Brookfield Reservoir. These basins are filled from a pump station in the adjacent Yellow Creek. This complex of basins has no significant recharge from runoff given the basin's bermed perimeters, and the capacity, when full, total approximately 115 million gallons or 353 acre-feet. RESOP analysis is not available for this source but the 200 acre-feet needed for public confidence to comply with MDNR standards, will be excluded from the RESOP analysis of Brookfield City Lake instead. During a DOR these basins would provide approximately 200 days of raw water supply before being unusable. USGS low flow equations calculate the 7Q10 at .258 MGD which is well short of the daily raw supply needed to meet normal demand. Due to the extreme and prolonged nature of the DOR, Yellow Creek is not a dependable source of water. There for given the no pumping condition, the Brookfield Reservoir is not a viable source of water during extreme conditions.

The other Brookfield source is the Brookfield City Lake, which is also augmented with pumping from Yellow Creek. Due to mechanical issues with the pump station supplying the Lake in the early 2000's the lake was reported to be over 12' below normal pool, drastically reducing supply capacity. RESOP analysis on this lake

determined during DOR conditions the reservoir yield capacity is 0.180 MGD without augmenting from Yellow Creek. The current treated water normal demand on Brookfield's sources is 0.494 MGD, which corresponds to a raw water normal demand of 0.543 MGD. Comparing the reservoir yield capacity to the raw water normal demand equals a net negative source capacity of 0.363 MGD during DOR conditions.

The City of Marceline maintains two reservoirs and a creek pump station on Mussel Fork Creek to augment the reservoirs as needed. USGS low flow data shows that Mussel Fork Creek flow is not sufficient to pump during prolonged dry periods. The larger, New Marceline Lake serves as the primary source and is modeled to have a RESOP reservoir yield capacity of 0.448 MGD, without pumping, during the DOR. While the Old Marceline Reservoir, with the same conditions has a RESOP reservoir yield capacity of .060 MGD. The calculation of the Old Marceline Reservoir was provided from in the Missouri Water Supply System Study of 2013 (MDNR 2013). The system does have the capability to pump water from the Old Reservoir to the New Marceline Lake and the water treatment facility. The Marceline water treatment facility was built in 2000 and maintains an average flow of approximately 1,250 gpm.

Marceline's two sources can combine for a daily reservoir yield of 0.454 MGD, which is less than the current treated demand of 0.508 MGD. The Marceline raw water normal demand is approximately 0.572 MGD, which results in a net negative reservoir yield capacity of 0.118 MGD. Combined with the net negative yield capacity of Brookfield, Cluster SW-2 has a total net negative yield capacity of 0.515 MGD. This analysis concludes that Cluster SW-2 sources are inadequate.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-2	Brookfield					0.494		0.376
	Laclede						100%	0.031
	Chariton-Linn PWSD #3						25%	0.351
	Bucklin						100%	0.017
	Mendon						100%	0.018
	Chariton PWSD #2						35%	0.049
	Marceline					0.520		0.257
	Chariton-Linn PWSD #3						75%	0.351
	Bucklin						100%	0.017
	Mendon						100%	0.018
Chariton PWSD #2						35%	0.049	


Results from USGS Low Flow Equations* for Stream Intakes in 10-county region									
Cluster	Supplier	PWS System ID	Intake	Inputs			Outputs		
				Drainage Area (Mi ²)	Length (mi)	Stream Variable	7Q10 (MGD)	30Q10 (MGD)	60Q10 (MGD)
SW-2	Marceline	2010497	Mussel Fork at Intake	146.7	55.6	0.695	0.100	0.229	0.284
SW-2	Brookfield	2010105	West Yellow Creek at intake	195.27	54.7	0.659	0.258	0.546	0.723

* Computed Statistics at Streamgages, and Methods for Estimated Low-Flow Frequency Statistics and Development of Regional Regression Equations for Estimating Low Flow Frequency Statistics at Ungaged Locations in Missouri, (USGS 2013)


Inactive Sources Within Cluster						
System ID#	type	System Name	County	Source	Year of Closure	
MO2010112	Surface Water	Bucklin	Linn	Inadequate lake (shallow and heavily silted); struggled with disinfection-by-products; closed plant; now purchase water from Chariton-Linn #3.	2010	
MO2010185	Groundwater	Laclede	Linn	Failed shallow wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Brookfield	1980	
N/A	Surface Water	Ethel	Macon	Inadequate lake (shallow and heavily silted); closed inadequate treatment plant; adsorbed by Chariton-Linn #3	1990	
N/A	Surface Water	New Cambria	Macon	Inadequate lake (shallow and heavily silted); closed inadequate treatment plant; adsorbed by Chariton-Linn #3	1990	
N/A	Groundwater	Sumner	Chariton	Failed shallow wells with declining yield; closed plant; adsorbed by Chariton-Linn #3	2008	
MO2010514	Groundwater	Mendon	Chariton	Failed shallow wells (declining yield, high in iron); closed plant; now purchase water from Chariton-Linn #3	2004	
N/A	Groundwater	Rothville	Chariton	Failed shallow wells (declining yield, high in iron); closed plant; adsorbed by Chariton-Linn #3	1990	
N/A	Surface Water	Lake Nehai Tonkayea	Chariton	Inadequate treatment plant; difficulty maintaining qualified operator; closed plant; adsorbed by Chariton-Linn #3	1990	

Cluster	Lake/ Reservoir	Cluster Current Demand		Raw Water Yield: Without Pumping, With Sediment Loading		Excess Capacity (Cluster Yield-Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
		Normal Treated (MGD)	Normal Raw (MGD)	Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
SW-2	Brookfield Lake			0.180			S, R	1959	107.9	2070.3	1948.18
SW-2	Brookfield Reservoir			n/a	0.600		S	1952	63.4	n/a	n/a
SW-2	Marceline Lake	1.014	1.115	n/a		-0.515	S	1928	61.2	n/a	n/a
SW-2	Marceline Lake (New)			0.420			S, R	1980	172.8	1990	1812

Brookfield Lake with Low Limit of 215 AC-FT Storage from 1951 to 1959




Marceline Lake with Low Limit of 178 AC-FT Storage from 1951 to 1959



Cluster SW-3

Source Inadequate



There is currently one source for Cluster SW-3, operated by the City of Unionville, Missouri. Lake Mahoney, which is a 187-acre water supply reservoir, sits at the headwaters to Lake Thunderhead. Lake Thunderhead is a private recreation lake that covers 1,140 acres. The City owned, Lake Mahoney, was originally used for water supply but due to its inadequate size, silting, and high organic content, the City draws water from Thunderhead. It is understood that the agreement between the Lake Thunderhead Homeowners Association and the City of Unionville is not recorded in writing. For this reason Lake Thunderhead is not considered a viable long-term source of water and will not be included in the evaluation.


The service area for water from Unionville is predominately Putnam County. The Source Cluster SW-3 map above depicts a large region that is supplied by the City of Unionville. Examination of the Average Daily Production and Demand table on the next page reveals, less than 1 percent of the water to Adair County PWSD #1 is provided by Unionville through Putnam County PWSD #1. None of the water from Unionville enters the Macon County PWSD #1 system. Because of the limited distribution piping detail these relationships are best evaluated in conjunction with the Production and Demand table data. Adair County PWSD #1 purchases less than 5,000 gallons a day to provide for a few customers near Putnam County PWSD #1 service area. Since 1985, records indicate no closed sources within this cluster. Portions of the water treatment facility were upgraded in 2015 to reduce disinfection-by-products and to improve operability of the facility. The decay and siltation of Lake Mahoney will continue to degrade water quality and will remain the limiting factor in the sustainability of dependable water for the communities it serves.

RESOP analysis shows that Lake Mahoney reservoir yield capacity during the DOR is 0.200 MGD. The treated water normal demand for the cluster is 0.330 MGD (or .363 MGD raw water), which results in a net negative raw water daily capacity of 0.163 MGD. Due to this net negative capacity, Cluster SW-3 by analysis has an inadequate source.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-3	Unionville					0.33		0.165
		Putnam County PWSD #1					68%	0.207
		Lake Thunderhead HOA					100%	0.021
		Adair PWSD #1					0.75%	0.463
		Brashear					100%	0.014
		LaPlata					100%	0.079
		Novinger					100%	0.026
		Macon County PWSD #1					1%	0.014
		Callao					100%	0.024
		Clarence					100%	0.065
	Elmer					100%	0.005	


Cluster	Lake/Reservoir	Cluster Current Demand	Raw Water Yield: Without Pumping, With Sediment Loading		Excess Capacity (Cluster Yield-Cluster Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
			Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
SW-3	Unionville Reservoir	Normal Treated (MGD) 0.33	0.200	0.200	-0.163	S, R	1941	73.5	620	430

Lake Mahoney with Low Limit of 190 AC-FT Storage from 1951 to 1959



Cluster SW-4

Source Inadequate




There is currently one source for Cluster SW-4, which is operated by Trenton Municipal Utilities of Trenton, Missouri. Water is pulled from the Thompson River via intake, and pumped to two raw water storage reservoirs. When these reservoirs are full, and have minimum sediment they have a total capacity of 164.5 million gallons. The North Reservoir has a maximum capacity of 140 million gallons and the South Reservoir has a maximum capacity of 24.5 million gallons. From these reservoirs Trenton Municipal Utilities produces approximately 1.72 MGD of treated water which serve the city of Trenton and customers of Grundy County PWSD #1. The water treatment plant is designed to produce 3,000 gpm and is understood to be in serviceable condition.

Since 1985 two communities in this cluster have abandoned water treatment activities and now purchase water from Grundy PWSD #1. The Inactive Systems table on the next page identifies those communities and briefly describes the reasoning for closure.

To produce 1.720 MGD of treated water approximately 1.892 MGD of raw water is need, due to treatment losses. Summing the entire volume of the reservoirs and dividing it by 1.892 MGD approximates 86.9 days of supply. The Minimum Design Standards for Missouri Community Water Systems recommends a 120 day surplus reserve storage after predicted depletion levels during a prolonged severe drought should be considered (MDNR 2013). Trenton does not have 120 days of surplus reserve storage under normal conditions. The reservoirs are bermed (meaning limited rain recharge) and depend on flow from the Thompson River and therefore also look at 3.1.1.f, which suggests a 7 Q 10 evaluation of the source. The Observed Stream Gauge Data from the Thompson River at Trenton, Missouri USGS Site from 1954-1957 shows prolonged periods of low flow. It is important to note that the minimum flow must be above 9 cfs for pumping to occur from the river as noted in the Missouri Water Supply Study (MDNR 2013). The intake pumps rated at 3,125 gpm (6.96 cfs), but the flow must be above 16 cfs to pump at full capacity. At 3,125 gpm the current demand of 1.892 gallons can be pumped in approximately 10 hours. Given that Trenton has less than 120 days of storage and documents periods of insufficient flow in the Thompson River to pump water, Cluster SW-4 by analysis to have an inadequate source.

Observed Stream Gauge Data from Thompson River @Trenton, MO USGS Site from 1954-1957



Graph 1 Observed Stream Data from Thompson River at Trenton, MO

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)						
Source Cluster	Tier System			MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd			
SW-4	Trenton Municipal Utilities			1.718		1.477
	Grundy County PWSD #1				100%	0.241
		Galt			100%	0.021
		Spickard			100%	0.028


Inactive Sources Within Cluster					Year of Closure
System ID#	type	System Name	County	Source	
MO2010300	Groundwater	Galt	Grundy	Failed shallow wells (declining yield, high in iron); closed plant; now purchase water from Grundy PWSD #1	1990
MO2010753	Groundwater	Spickard	Grundy	Failed shallow wells (declining yield); closed plant; now purchase water from Linn-Livingston #3	1985

Results from USGS Low Flow Equations* for Stream Intakes in 10-county region									
Cluster	Supplier	PWS System ID	Intake	Inputs			Outputs		
				Drainage Area (MI ²)	Length (mi)	Stream Variable	7Q10 (MGD)	30Q10 (MGD)	60Q10 (MGD)
SW-4	Trenton	2010796	Thompson River at Intake	1722.3	155.46	0.714	6.268	8.673	12.949

* Computed Statistics at Streamgages, and Methods for Estimated Low-Flow Frequency Statistics and Development of Regional Regression Equations for Estimating Low Flow Frequency Statistics at Ungaged Locations in Missouri, USGS 2013

Cluster SW-5

Source Inadequate



There is currently two sources for Cluster SW-5, Forest Lake and Hazel Creek Lake, which are operated by the City of Kirksville, Missouri. Water is pulled, from the Forest Lake or Hazel Creek Lake, via intakes and pumped to the treatment facility to a 7-million gallon, earthen, pretreatment settling basin. The 585-acre Forest Lake is owned by the State of Missouri and is operated as a Thousand Hills State Park. The 501.7 acre Hazel Creek Lake is owned and operated by the City of Kirksville. Both lakes' primary purposes are recreation with a secondary purpose of water supply. Dependent upon routine water quality tests, operators pump water from either lake to the pretreatment basin. This basin is located at the water treatment plant is sized to provide approximately two days of raw water storage.

Since 1985, two communities in this cluster have abandoned water treatment activities and purchase water from secondary system of Kirksville, Adair County PWSD #1 and Macon County PWSD #1. The Inactive Systems table on the next page identifies those communities and briefly describes the reasoning for closure.

To calculate the lower limits for RESOP modeling the first step was to evaluate the bathymetry provided by USGS. Based upon this data which provided reservoir elevations and corresponding volumes in acre-feet, the known elevation of inlets was noted and a minimum depth over the inlet was selected. In this case the inlet elevations site higher than the bottom one-third elevation change from the total elevation given by the bottom of reservoir to spillway elevation. The unusable volume according to this calculation was set at 2,120 acre-feet for Forest Lake and 1,450 acre-feet for Hazel Creek Lake

For RESOP modeling and evaluation purposes only one source can be evaluated at a time so a proportional demand approach was used in this evaluation similar to the approach in the Missouri Water Supply Study (MDNR 2013). The proportions were calculated by dividing each sources daily reservoir yield capacity by the daily cluster yield capacity. Running RESOP analysis using the lower limits described previous, the individual reservoir yields for Forest and Hazel Creek lakes were 2.69 MGD and 1.48 MGD respectively. To calculate the proportional demand the individual reservoir yields were divided by the total combined yield, 4.43 MGD, resulting in Forest

Lake yields 66.7% (2.95 MGD of the total 4.43 MGD) and Hazel Creek Lake yields the remaining 33.3 percent (1.265 MGD of the total 4.43 MGD) of the total combined yield. In addition, the Design Standards of Missouri Community Water Systems a suggested minimum of 120 days of surplus storage beyond predicted depletion levels during a prolonged and severe drought for public confidence. The 2015 treated water demand, found in the Average Daily Production and Demand table, was 3.432 MGD. This correlates to an approximate total average daily raw water demand of 3.775 MGD or proportionally, 2.510 MGD (3.775 multiplied by 66.6 percent) from Forest Lake and 1.265 MGD (3.775 multiplied by 33.3 percent) from Hazel Creek Lake.

To comply with Missouri minimum design standards these proportional demands must be multiplied by 120 days, corresponding to 301.2 MG for Forest Lake and 151.2 MG for Hazel Creek. Converting the public confidence volumes to acre-feet will allow the RESOP analysis to be reevaluated for a new lower limit that includes public confidence. To convert gallons to acre feet the following calculation was used:

$$\times \text{ --- } \times \text{ --- } =$$

The consumer confidence for Forest Lake equals 924 acre-ft. and 464 acre-ft. for Hazel Creek Lake, which corresponding to new lower limits of 3044 acre-ft. and 1914 acre-ft., respectively. Given the new lower limit the reservoir yields were recalculated in RESOP to be 3,044 acre-ft. (Forest Lake) and 1,914 acre-ft. (Hazel Creek Lake). The new reservoir yield for the two supplies, inclusive of public confidence, are 2.69 MGD (Forest Lake) and 1.35 MGD (Hazel Creek Lake), for a total cluster yield capacity of 4.04 MGD. To compare the current normal demand treatment losses must be accounted for, this is done by adding a 10 percent factor of the treated demand from 2015. The average daily treated water quantity is shown in the Production and Demand table below, and totals 3.432 MGD. Adding 10% the raw water used on an average day in 2015 was 3.775 MGD. Subtracting this demand from the combined reservoir yield equals 0.265 MGD of excess capacity.


In December 2015, Kraft-Heinz Company announced a \$250 million expansion of the Kraft Foods/ Oscar Mayer plant located in Kirksville, Missouri (Hunsicker 2016). City staff it was indicated in correspondence with Allstate that the expansion would increase the daily demand by approximately 0.350 MGD of treated water to the facility. This increase in demand is not reflected in the 2015 demand data but is important in this evaluation. Adding the impending raw water demand of 0.385 MGD or (0.350 MGD x 1.1=raw demand) to the 3.775 MGD of current demand totals 4.16 MGD, which is 0.125 MGD beyond the RESOP reservoir yield. Therefore, the sources of Cluster SW-5 are inadequate for the current and impending demand under DOR conditions.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-5	Kirksville					3.432		2.970
		Adair PWSD #1					99%	0.462
			Brashear				100%	0.014
			LaPlata				100%	0.079
			Novinger				100%	0.026
			Macon County PWSD #1				1%	0.139
				Callao			100%	0.024
				Clarence			100%	0.065
				Elmer			100%	0.005


Inactive Sources Within Cluster					
System ID#	type	System Name	County	Source	Year of Closure
MO2010587	Groundwater	Novinger	Adair	Failed shallow wells (declining yield); closed plant; now purchase water from Adair PWSD #1	2005
MO2010451	Surface Water	La Plata	Macon	Inadequate lakes; closed inadequate treatment plant; now purchase water from Adair PWSD #1	2000

Surface Water Supply(s) Within Cluster											
Cluster	Lake/ Reservoir	Cluster Current Demand		Raw Water Yield: Without Pumping, With Sediment Loading		Excess Capacity (Cluster Yield- Cluster Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
		Normal Treated (MGD)	Normal Raw (MGD)	Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
SW-5	Forest Lake*	2.51	2.76	2.691	4.040	-0.120	R, S	1951	585.2	12500	10,380
SW-5	Hazel Creek Lake*	1.27	1.40	1.349	4.040		R, S	1982	501.7	8680	7,230

Hazel Creek with Low Limit of 1914 AC-FT Storage from 1951 to 1959




Forest Lake with Low Limit of 3044 AC-FT Storage from 1951 to 1959



Cluster SW-6

Source Adequate



There is currently one source for Cluster SW-6, Long Branch Lake, which is operated by the U.S. Army Corps of Engineers. The primary purpose of Long Branch Lake is flood control, with secondary purposes of water supply and recreation. Macon Municipal Utilities (MMU) has purchased rights to 4,400 acre-feet of water supply storage within the reservoir. According to MMU this is approximately 36 percent more capacity than the current demand. The current treated water demand for Cluster SW-6 is 2.50 MGD, as noted in the Production and Demand table on the next page.

Since 1985, three communities in this cluster have abandoned water treatment activities and now purchase water from the secondary system of Macon County PWSD #1. The Inactive Systems table on the next page identifies those communities and briefly describes the reasoning for closure.

A RESOP model was not developed for this source given known characteristics of the lake. Long Branch Lake has a total of 36,800 acre-feet at normal pool. Of that 24,400 acre feet are allocated for water supply storage. The rights to the remaining 20,000 acre-feet are held by the U.S. Army Corps of Engineers. For purposes of this evaluation only the 4,400 acre-feet will be considered as usable capacity.

The Missouri Water Supply Study did not evaluate Long Branch specifically, but it did mention it as a potential source of water for Sugar Creek Lake in Moberly, Missouri, as seen in the following (MDNR 2013)

“When flow in East Fork Chariton River is not sufficient for diversion, the city would be able to purchase water from Long Branch Reservoir at Macon. Water can be released from Long Branch Reservoir and allowed to flow downstream to the pump intake near Moberly. Moberly has been reporting East Fork Chariton River as a supply source beginning in 1992.

The volume of water that would be required by pumping from East Fork Chariton River:

1954.....	317.3 million gallons
1955.....	421.3 million gallons
1956.....	421.3 million gallons
1957.....	421.3 million gallons
1958.....	208.5 million gallons"

If this emergency release were needed, it is assumed it would come from the 20,000 acre-feet of water supply at a volume of nearly three times what is needed for pumping due to losses and capture rate. More information is needed to access this potential. This uncertainty is a reason for not including the currently unused water supply reserve in the cluster evaluation.

Cluster SW-6 has a total excess yield capacity of 0.650 MGD and, therefore, the source is adequate for the current demand under DOR conditions.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-6	Macon					2.5		
		Atlanta					100%	0.020
		Bevier					100%	0.056
		Macon County PWSD #1					89%	1.232
			Callao				100%	0.024
			Clarence				100%	0.065
			Elmer				100%	0.005

Inactive Sources Within Cluster					
System ID#	type	System Name	County	Source	Year of Closure
MO2010247	Groundwater	Elmer	Macon	Failed shallow wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Macon PWSD #1	1985
MO2010035	Surface Water	Atlanta	Macon	Inadequate lake; struggled with disinfection-by-products; closed plant; now purchase water from Macon	1985
MO2010125	Groundwater	Callao	Macon	Failed shallow wells (declining yield); closed plant; now purchase water from Macon PWSD #1	1990

Lake/ Reservoir	Cluster Current Demand		Raw Water Yield: Without Pumping, With Sediment Loading		Excess Capacity (Cluster Yield- Cluster Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
	Normal Treated (MGD)	Normal Raw (MGD)	Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
Long Branch Lake	2.5	2.75	3.400	3.400	0.650	C, S, R	1979	2682.8	8,680	7,230

Summary of Surface Water Cluster Evaluations

The six surface water clusters were evaluated under the assumptions of 50 years of sediment loading into reservoirs, DOR recharge rates, full reservoir capacity at beginning of time sequence, and that volume associated with the lower one-third reservoir elevation is unusable. Additionally, quantity standards in Chapter 3 of the Minimum Design Standards for Missouri Community Water Systems (MDNR 2013) were used to evaluate clusters reliability. The analysis ignores the predicted increases in drought length and severity caused by climate change and focuses on the ability of a source to meet current normal demand.

Totaling the 2015 normal demand of surface water clusters with inadequate sources during a drought, equal in magnitude to the DOR, equals 8.416 MGD. Note this total includes the impending demand (0.35 MGD) for Kirksville as noted in the Cluster SW-5 report. A complete listing of the Surface Water Cluster Production & Demand Table from 2015 is located in Appendix J. The impact of inadequate cluster water sources could result in the complete depletion of water in 5 of 6 the existing clusters. Figure 7, below, shows clusters with inadequate sources in red and Cluster SW-6, the only adequate source, in green. Each segment of the pie corresponds to a surface water producer within the 10 county region. The size of each segment is proportionate to the average daily demand produced by each system, shown as the value at the end of the labels in MGD.

A total of 11.401 MGD of treated surface water was produced in 2015 according to data provided by systems. The current regional trend, as shown by Baker 2015, is that systems have been abandoning treatment facilities and sources as they degrade beyond the point of serviceability or if they become too expensive to maintain.





Figure 7: Regional Surface Water Cluster Summary.

Overview of Groundwater Cluster Evaluations

The analysis of groundwater sources, is based on regional and local geology, historical data, and engineering design criteria. Specific well analysis cannot definitively predict how long or at what rate a well will yield water or what water quality. Therefore, this evaluation will summarize historic geologic findings from both the Missouri Geologic Survey and individual systems; review the history of wells (abandoned, active, inactive, plugged and boring results) within the region; and explain assumptions based on local engineering experience. A determination of a clusters adequacy to provide long-term, reliable water will be based on the evaluation criteria and will be included in the Groundwater Summary. Data used in this evaluation is based on individual system interviews, reports by USGS, MDNR, and individual well drillers. The Missouri Spatial Data Information Service (MSDIS) and Missouri Geologic Survey provided the GIS metadata.

The evaluation of groundwater sources for individual clusters is complicated by a host of variables that range from water quantity to quality. These factors are illuminated in the excerpt from Miller later in this section. This unpredictability goes beyond daily variation in water quality and/or hydraulic head, but can change without notice and render a well permanently useless for supply. This uncertainty and known required maintenance of wells serves as the basis for MDNR recommendation to have redundant sources for groundwater supplies for communities as outlined in Chapter 3 Section 2.1.2 of the Minimum Design Standards for Missouri Community Water Systems.

As of 2016, MDNR data confirms that four of the 10 counties in the study region of north-central Missouri have public drinking water facilities that use a groundwater source for raw water (MDNR 2016). These include: Chariton, Linn, Livingston, and Mercer counties. State wide, 13 counties in Missouri which do not have a single groundwater source system, see Figure 8 below. Six of those 13 are within the 10-county study area, and all 13 are located north of the Missouri River. Additionally, four of the 13 counties outside of the study area are directly adjacent to the study area. Buchanan County, which is outside of the study area, does not have a public water



treatment system, and is served by Missouri River alluvium groundwater wells from a supplier in adjacent Andrew County.

The distinct lack of groundwater-type public water systems in the northern part of Missouri, as depicted in Figure 8, is based on the hydrogeology of the region. The following excerpt is from the Groundwater Resources of Missouri, which is Volume III of the Missouri State Water Plan Series. The excerpt summarizes hydrogeology the Northwestern Province of Missouri, which overlays seven of the western counties in the region of study.

“Groundwater resources in much of northwest Missouri are poor. The thick carbonate aquifers that supply large quantities of high-quality water in the Ozarks and east central Missouri are also present at great depth in the northwestern part of the state. In northwest Missouri they yield water so highly mineralized that, for practical purposes, it is unusable. Bedrock formations in the Northwestern Missouri groundwater province older than Pennsylvanian-age yield highly-mineralized water. Usable quantities of groundwater are locally available from Pennsylvanian strata, but yields are typically low and the water quality is marginal. Glacial deposits, depending on thickness and texture, can yield from zero to more than 500 gpm. Except for the Missouri River alluvium, alluvial deposits in northwestern Missouri generally yield small quantities of water. This is because the alluvial sediments of the smaller rivers are finer grained and more poorly-sorted than those of the Missouri River. However, there are significant exceptions to this, especially near the mouths of major northwest Missouri rivers where the alluvium may yield quantities of water suitable for irrigation or public water supply. Many years ago, geologists recognized that the stratigraphy and geomorphology of this area are so complex and site specific that it is difficult to predict either the lithologic character or the thickness of material likely to be encountered at any drill site. So, in 1956, using funds provided by the Missouri Legislature, the Missouri Geological Survey (now the Division of Geology and Land Survey) began an ambitious test drilling program to determine the thickness and character of the glacial drift in the Northwestern Missouri groundwater province. The project, which ended in 1960, included 19 of the 23 counties in the province. These drilling studies did much to help northwest Missouri towns and rural residents develop safer, more reliable water supplies. The four northwestern Missouri counties excluded from detailed drilling studies were found not to contain appreciable thicknesses of permeable glacial drift materials. Limited funds prevented their study, as well as a similar study to cover the northeastern part of the state. Table 14 is a listing of county studies available for the area. The studies are a valuable aid to finding and developing water supplies. Groundwater storage estimates for northwest Missouri included with this report rely heavily on the data collected during the 1950s” (MDNR 1997).

The available groundwater data set is the Public Water Wells data set, which provides information about wells in the state of Missouri. The parent data set is the Wellhead Information Management System (WIMS) database that is maintained by the MDNR, Missouri Geological Survey, Geological Survey Program, and Wellhead Protection Section. The WIMS database resulted from implementation of the Water Well Drillers Law of 1985. The information about well location, well ownership, well completion date, well construction, well yield, static water level, and borehole stratigraphy was provided by well drillers as required by state statute RSMo 256.600-256.640. Wells drilled prior to July of 1987 are not included in this data set. A WIMS well search is also available online at <http://dnr.mo.gov/mowells/publicLanding.do>.

A database of public drinking wells, including closure information, was not required until after the 1996 amendment to the Safe Drinking Water Act. The Safe Drinking Water Information System (SDWIS) database is historically incomplete for many small rural systems that have drilled dozens of wells over the last 100 years and plugged those that became inadequate or untreatable. Planners and engineers are left to evaluate groundwater availability and reliability based on regional geologic reports and community-specific records as available.

Figure 9, below, was developed with the metadata provided by Missouri Geologic Survey in the Well Log data set. The data was originally from the 1950's exploration Miller referenced filtered to provide a graphical representation of the over 500 wells drilled to evaluate the geology of the area. The drillers' logs, which included yield information, are grouped by color and size, and the borings, which did not include yield data are marked with "x." The drillers' notes of potential yield were given in ranges; for example, the highest yielding test hole, located in Putnam County, had a noted range of 500-1,000 gpm. The other potentially high yielding test hole was in Mercer County and was noted to have a potential yield of 300-600 gpm. For purposes of the graphic, the high-range value was used on the entire data set. Schuyler, Adair, and Macon counties were not included in the 1950s study.





Figure 9: 1950s Exploratory Test Holes in Northwest Missouri

Groundwater Cluster Reports GW-1 to GW-9

Cluster GW-1

Sources Inadequate



Cluster GW-1 is supplied by three groundwater wells and is owned and operated by the City of Keytesville, Missouri. MDNR records indicate that wells #1 through #3 are inactive, and last recorded yields were 11, 10 and 7 gpm respectively. Collectively, the old wells yielded a total 28 gpm for a full 24 hours which would produce approximately 0.032 MGD. This constant draw was still short of needs, causing the City to drill three replacement wells. The current wells, Well #4, #5, and #6, are documented as producing 0.053 MGD (or 36 gpm) each. The treatment facility is designed for a maximum flow of 115 gpm (or .138 MGD @ 20 hours of run time) and is listed as an iron removal type, which was likely a contributing factor to the decline in yield from wells #1-3.

It is important to note that the wells in this cluster are within 8 miles of the Missouri River channel and 2 miles of the Chariton River channel. The wells are located in modern alluvium, near major streamflows, which is uncharacteristic for the majority of the sources in the evaluated 10 county region. This proximity can be misleading to the long-term dependability of wells. Given the history of declining wells, this evaluation has identified Cluster GW-1's sources as inadequate.

The Daily Production and Demand table below details Chariton PWSD #2 purchases approximately 0.022 MGD from Keytesville.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-1	Keytesville					0.0530		0.031
	Chariton PWSD #2						45%	0.049

Keytesville


PWSS No. 2010420

3 Wells, Chariton County

Prepared by:



Map Update: Jan 22, 2016



Well System

H System Well

SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer

SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey
(USGS) publication: "Topographic Map Symbols."



Although all data in this dataset have been used by the Missouri Department of Natural Resources (MDNR), no warranty, expressed or implied, is made by MDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>

Keytesville

PWSS No. 2010420

Chariton County

3 wells

Prepared by:



Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W4	W5	W6
Extended PWS #	2010420104	2010420105	2010420106
Local Well Name	replaces Well #1	replaces Well #2	replaces Well #3
Well ID #	18053	18054	18055
DGLS ID #	_____	_____	_____
Facility Type	City	City	City
Status	Active	Active	Active
Latitude	39.42094	39.4194	39.41936
Longitude	-92.93667	-92.9366	-92.93467
Location Method	GPS	GPS	GPS
Method Accuracy (ft)	98	98	98
USGS 7.5 Quadrangle	Keytesville	Keytesville	Keytesville
County	Chariton	Chariton	Chariton
MoDNR Region	Northeast	Northeast	Northeast
Date Drilled (year)	2004	2004	2004
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Alluvium	Alluvium	Alluvium
Total Depth Formation	Pennsylvanian	Pennsylvanian	Pennsylvanian
Total Depth	52	50	49
Ground Elevation (ft)	_____	_____	_____
Top Seal	Tremie Grout	Tremie Grout	Tremie Grout
Bottom Seal	_____	_____	_____
Casing Depth (ft)	48	50	35
Casing Size (in)	24	24	24
Casing Type	Steel	Steel	Steel
Elev. of Casing Top (ft)	_____	_____	_____
Outer Casing Depth (ft)	_____	_____	_____
Outer Casing Size (in)	_____	_____	_____
Screen Length (ft)	_____	15	15
Screen Size (in)	_____	_____	_____
Static Water Level (ft)	12	8	11
Well Yield (gpm)	_____	_____	_____
Head (ft)	_____	_____	_____
Draw Down (ft)	_____	_____	_____
Pump Test Date (year)	_____	_____	_____
Pump Type	_____	_____	Submersible
Pump Manufacturer	_____	_____	Grundfos
Pump Depth (ft)	20	18	18
Pump Capacity (gpm)	150	150	150
Pump Meter (Y/N)	_____	_____	_____
VOC Detection (Y/N)	_____	_____	_____
Nitrate Detection (Y/N)	_____	_____	_____
Chlorination (Y/N)	_____	_____	_____
Filtration (Y/N)	_____	_____	_____
GWUDISW (Y/N)	_____	_____	_____
Surface Drainage	_____	_____	_____
State Approved(Y/N)	_____	_____	_____
Date Abandoned (year)	_____	_____	_____
Date Plugged (year)	_____	_____	_____

Cluster GW-2

Sources Adequate



Cluster GW-2 is supplied by groundwater wells and is owned and operated by the Missouri American Water Company - Brunswick. The data for the following table was based on MDNR Sanitary Survey's and was accessed via the Drinking Water Watch website (MDNR 2016). Note that the Well #3 yield (MGD) was calculated from the Yield (gpm) x 1,440 (60 minutes/hour x 24 hours/day). The limiting factor is the treatment facility which is designed for a maximum flow of 300 gpm or 0.360 MGD (based on 20 hours of run time). It is important to note that Well #3 in this cluster is within 800 feet of the Grand River channel and 4,300 feet of the Missouri River channel. Given the immediate proximity to a major stream flow, location in modern alluvium, and no known history of declining yield, Cluster GW-2's source is identified as adequate.

Missouri American - Brunswick	Yield (gpm)	Yield (MGD)	Pump Capacity (gpm)	Design Rate (gpm)
Well #1	19	0.028	150	
Well #2	52	0.075	150	
Well #3	715	1.030	400	
Treatment Plant				300

The treated water demands of 2015 are shown in the following table.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-2	Mo American Brunswick					0.0841		0.057
		Chariton PWSD #2					55%	0.049

Mo American - Brunswick

PWSS No. 2010109

3 Wells, Chariton County


Map Update: Jan 22, 2016

Missouri Department of
Natural Resources



R20W

R19W



Well System

H System Well

SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Chariton



Miles



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey
(USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Mo American - Brunswick

PWSS No. 2010109

Chariton County

3 wells

Prepared by:



Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W1	W2	W3
Extended PWS #	2010109101	2010109102	2010109103
Local Well Name	Well #1	Well #2	Well #3
Well ID #	14612	14613	14614
DGLS ID #	_____	_____	_____
Facility Type	City	City	City
Status	Active	Active	Active
Latitude	39.41411	39.41281	39.39561
Longitude	-93.11311	-93.11311	-93.11361
Location Method	DRG/MAP	DRG/MAP	DRG/MAP
Method Accuracy (ft)	33	33	33
USGS 7.5 Quadrangle	Brunswick East	Brunswick East	Brunswick East
County	Chariton	Chariton	Chariton
MoDNR Region	Northeast	Northeast	Northeast
Date Drilled (year)	1951	1952	1982
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Alluvium	Alluvium	Alluvium
Total Depth Formation	Alluvium	Alluvium	Alluvium
Total Depth	65	65	82
Ground Elevation (ft)	_____	_____	_____
Top Seal	Pump Base	Pump Base	Mechanical Seal
Bottom Seal	Steel Plate	Steel Plate	Steel Plate
Casing Depth (ft)	26	26	31
Casing Size (in)	24	24	24
Casing Type	Steel	Steel	Steel
Elev. of Casing Top (ft)	644	644	640
Outer Casing Depth (ft)	_____	_____	_____
Outer Casing Size (in)	_____	_____	_____
Screen Length (ft)	20	20	25
Screen Size (in)	12	12	16
Static Water Level (ft)	15	15	4
Well Yield (gpm)	200	150	750
Head (ft)	_____	_____	_____
Draw Down (ft)	5	11	5
Pump Test Date (year)	1993	1993	1993
Pump Type	Submersible	Submersible	Submersible
Pump Manufacturer	Crown	Crown	Crown
Pump Depth (ft)	52	52	_____
Pump Capacity (gpm)	160	160	160
Pump Meter (Y/N)	Y	Y	Y
VOC Detection (Y/N)	N	N	N
Nitrate Detection (Y/N)	N	N	N
Chlorination (Y/N)	Y	Y	Y
Filtration (Y/N)	Y	Y	Y
GWUDISW (Y/N)	N	N	N
Surface Drainage	Satisfactory	Satisfactory	Satisfactory
State Approved(Y/N)	Y	Y	Y
Date Abandoned (year)	_____	_____	_____
Date Plugged (year)	_____	_____	_____

Cluster GW-3

Sources Adequate



Cluster GW-3 is supplied by groundwater wells and is owned and operated by Chillicothe Municipal Utilities. MDNR records indicate six active alluvial wells ranging in yield from 650-1,000 gpm each and are located in the alluvium for the Grand River. The iron removal type water treatment plant has a design capacity of 2,200 gpm or 2.64 MGD (running for 20 of 24 hours a day).

The Production and Demand table details the three wholesale customers and their customers. Livingston County PWSD #2 utilizes treated water from Chillicothe for approximately 49 percent of their total demand. In 2015, Chillicothe Municipal Utilities produced approximately 60 percent of the total groundwater in the 10-county study region. Livingston PWSD #1, closed its groundwater treatment plant in 2005 after well yield declined below demand and approximately 28 test wells failed to produce a viable solution. This information is included in Appendix C.

Given the immediate proximity to major modern alluvium and stream flow, Cluster GW-3 is identified as having adequate sources.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-3	Chillicothe Municipal Utilities					1.3		0.893
	Livingston Co. PWSD #1						100%	0.077
	Livingston Co. PWSD #2						49%	0.151
	Chula						100%	0.016
	Livingston Co. PWSD #3 East						100%	0.197
	Hale						100%	0.043

Chillicothe Municipal Utilities

PWSS No. 2010162

6 Wells, Livingston County

Prepared by:

Map Update: Jan 22, 2016




Missouri Department of
Natural Resources

R24W

R23W

T58N

T57N




Well System

H System Well


SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Miles



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
 For basemap symbols, see the U.S. Geological Survey
 (USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Chillicothe Municipal Utilities

PWSS No. 2010162

Livingston County, sheet 1 of 2

6 wells

Sheet Update: Jan 25, 2016

Prepared by:



Missouri Department of
Natural Resources

Well Number	W1	W2	W3	W4	W5
Extended PWS #	2010162101	2010162102	2010162103	2010162104	2010162105
Local Well Name	Well #1	Well #2	Well #3	Well #4	Well #5
Well ID #	13827	13828	13829	13830	16992
DGLS ID #				029061	
Facility Type	City	City	City	City	City
Status	Active	Active	Active	Active	Active
Latitude	39.77485	39.77456	39.77146	39.77177	39.758125
Longitude	-93.5634	-93.56816	-93.56101	-93.55383	-93.575196
Location Method	DRG/MAP	DRG/MAP	DRG/MAP	DRG/MAP	PLSS
Method Accuracy (ft)	33	33	33	33	800
USGS 7.5 Quadrangle	Chillicothe	Chillicothe	Chillicothe	Chillicothe	Chillicothe
County	Livingston	Livingston	Livingston	Livingston	Livingston
MoDNR Region	Northeast	Northeast	Northeast	Northeast	Northeast
Date Drilled (year)	1968	1971	1971	1993	
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Glacial Deposits	Glacial Deposits	Glacial Deposits	Glacial Deposits	Glacial Deposits
Total Depth Formation	Glacial Deposits	Glacial Deposits	Glacial Deposits	Glacial Deposits	Glacial Deposits
Total Depth	105	120	126	110	135
Ground Elevation (ft)	676	676	682	659	682
Top Seal	Mechanical Seal	Mechanical Seal		Cement Grout	Cement Grout
Bottom Seal	Steel Plate	Steel Plate		Cement Grout	Gravel Pack
Casing Depth (ft)				75	115
Casing Size (in)				18	18
Casing Type	Steel	Steel	Steel	Steel	Steel
Elev. of Casing Top (ft)					
Outer Casing Depth (ft)				30	20
Outer Casing Size (in)				42	48
Screen Length (ft)	25	30	28	35	20
Screen Size (in)	18	18	18	18	18
Static Water Level (ft)	38	37	42	18	
Well Yield (gpm)	700	700	650	950	
Head (ft)	154	186	150		158
Draw Down (ft)	30	31	24	32	
Pump Test Date (year)	1991	1991	1991	1992	
Pump Type	Vertical Turbine	Vertical Turbine	Vertical Turbine	Submersible	Vertical Turbine
Pump Manufacturer	Layne & Bowler	Layne & Bowler			
Pump Depth (ft)	80	80	60	86	
Pump Capacity (gpm)	1000	1000	1000	950	1000
Pump Meter (Y/N)	Y	Y	Y	Y	
VOC Detection (Y/N)	Y	N	N	N	
Nitrate Detection (Y/N)	N	N	N	N	
Chlorination (Y/N)	Y	Y	Y	Y	
Filtration (Y/N)	Y	Y	Y	Y	
GWUDISW (Y/N)	N	N	N	N	
Surface Drainage	Satisfactory	Satisfactory			
State Approved(Y/N)	Y	Y	Y	Y	
Date Abandoned (year)					
Date Plugged (year)					

Chillicothe Municipal Utilities

PWSS No. 2010162

Livingston County, sheet 2 of 2

6 wells

Prepared by:

Sheet Update: Jan 25, 2016



Missouri Department of
Natural Resources

Well Number	W8
Extended PWS #	2010162108
Local Well Name	Well #6
Well ID #	18865
DGLS ID #	_____
Facility Type	City
Status	Active

Date Drilled (year)	_____
Material (C/U)	Unconsolidated
Base of Casing Formation	Glacial Deposits
Total Depth Formation	Glacial Deposits
Total Depth	_____
Ground Elevation (ft)	682
Top Seal	Cement Grout
Bottom Seal	Cement Grout


Static Water Level (ft)	_____
Well Yield (gpm)	_____
Head (ft)	_____
Draw Down (ft)	_____

VOC Detection (Y/N)	_____
Nitrate Detection (Y/N)	_____
Chlorination (Y/N)	_____
Filtration (Y/N)	_____

Date Plugged (year)	_____
---------------------	-------

Cluster GW-4

Sources Inadequate



Cluster GW-4 is supplied, in part, by a groundwater well owned and operated by Livingston County PWSD #2. Missouri DNR records indicate the well was drilled in 2013 and yields approximately 276 gpm. The iron removal water treatment plant was designed for a maximum flow of 230 gpm. Based on 2015 annual average water production and demand data from the district, the well produces approximately 51 percent (0.087 MGD) of the total system demand (0.167 MGD). The remaining 49 percent (0.080 MGD) is purchased from Chillicothe Municipal Utilities. Note demand and production numbers do not equate, this error is attributed to water loss within the system by conversation with system staff.

The City of Chula began purchasing water from Livingston County PWSD #2 in 1985 after closing its water treatment plant after declining yield limited its capacity.

Well log data shows that Livingston County PWSD #2 has two inactive wells, Well #1 drilled in 1964 and Well #2 drilled in 1988. The data does not indicate a date of closure for the wells. The glacial deposit formation, which the wells are documented as located in, is known to contain high iron and varying quantities of water. Well #2 was drilled to a total depth of 139 feet below the surface and had a static water level of 53 feet below the surface. Drawdown information lists the depth at 110 feet below the surface when the 250 gpm pump was running. This slow recharge is an important factor in the reliability of a groundwater well. Additional information on Well #1 and Well #2 is located in Appendix F. Given the history of declining wells, this evaluation has identified Cluster GW-4's sources as inadequate.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-4	Livingston Co. PWSD #2					0.087	52%	0.151
	Chula						100%	0.016

Livingston Co. PWSD #2

PWSS No. 2024353

1 Well, Livingston County


Prepared by:

Map Update: Jan 22, 2016



Missouri Department of
Natural Resources

R23W




Well System

H System Well

SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Feet



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey (USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Livingston Co. PWSD #2

PWSS No. 2024353

Livingston County

1 well

Prepared by:



Sheet Update: Jan 25, 2016



Missouri Department of
Natural Resources

Well Number	W3
Extended PWS #	2024353103
Local Well Name	Well #3
Well ID #	18764
DGLS ID #	_____
Facility Type	Water District
Status	Active


Date Drilled (year)	2013
Material (C/U)	Unconsolidated
Base of Casing Formation	Alluvium
Total Depth Formation	Alluvium
Total Depth	185
Ground Elevation (ft)	775
Top Seal	Cement Grout
Bottom Seal	Cement Grout

Static Water Level (ft)	95
Well Yield (gpm)	276
Head (ft)	_____
Draw Down (ft)	_____

VOC Detection (Y/N)	_____
Nitrate Detection (Y/N)	_____
Chlorination (Y/N)	_____
Filtration (Y/N)	_____

Cluster GW-5

Sources Inadequate



Cluster GW-5 is supplied by five groundwater wells and is owned and operated by Linn County Consolidated PWSD #1. The 2015 average daily treated water normal demand for this cluster was 0.085 MGD and serves approximately 1,620 people. Missouri DNR records and information from district staff was used to develop the Water Yield and System Capacities table below. Note that Well #3 is not used due to its high iron content.

Water Yield and System Capacities				
Linn Co. Cons. PWSD #2	Yield (gpm)	Yield (MGD)	Pump Capacity (gpm)	Design Rate (gpm)
Well #1	32	0.046	41	
Well #2	41	0.059	75	
Well #3	-	-	75	
Well #4	75	0.108	75	
Well #5	20	0.029	25	
Treatment Plant				200

The letter in Appendix B describes the 2003 test hole activities, where 11 test holes were unsuccessful in identifying an alluvial well capable of producing 50 gpm. The map included in the letter is duplicated on the next page and shows the 33 test holes drilled by Brotcke Well and Pump from 1966 to 2003. Based on the history of the wells in this cluster to be influenced by high iron content, and because of continued deterioration of existing wells and the difficulty in identifying new wells, long-term water reliability within Cluster GW-5 is uncertain, therefore, its sources are identified as inadequate.

93.21667° W

WGS84 93.20000° W




City of Purdin
Linn County CPWSD No 1
Test Hole Summary

39.98333° N

39.96667° N


39.98333° N

39.96667° N



93.21667° W

WGS84 93.20000° W



Linn Co. Cons. PWSD #1

PWSS No. 2024346

5 Wells, Linn County

Prepared by:




Missouri Department of
Natural Resources

Map Update: Jan 22, 2016

R20W

R21W



Well System


H System Well

SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer

SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey (USGS) publication: Topographic Map Symbols.



Linn



Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>

Linn Co. Cons. PWSD #1

PWSS No. 2024346

Linn County

5 wells

Prepared by:

Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W1	W2	W3	W4	W5
Extended PWS #	2024346101	2024346102	2024346103	2024346104	2024346105
Local Well Name	Well #1	Well #2	Well #3	Well #4	Well #5
Well ID #	13867	13868	13869	13870	18025
DGLS ID #	_____	_____	_____	_____	_____
Facility Type	Water District	Water District	Water District	Water District	Water District
Status	Active	Active	Active	Active	Active
Date Drilled (year)	1969	_____	_____	1997	_____
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated	Unconsolidated	_____
Base of Casing Formation	Alluvium	_____	_____	Alluvium	_____
Total Depth Formation	Alluvium	_____	_____	Alluvium	_____
Total Depth	78	_____	_____	72	_____
Ground Elevation (ft)	758	748	722	764	_____
Top Seal	Pitless Adapter	_____	_____	Cement Grout	_____
Bottom Seal	Cement Grout	_____	_____	_____	_____
Static Water Level (ft)	40	_____	_____	_____	_____
Well Yield (gpm)	_____	_____	_____	_____	_____
Head (ft)	_____	_____	_____	125	_____
Draw Down (ft)	_____	_____	_____	_____	_____
VOC Detection (Y/N)	N	N	N	N	_____
Nitrate Detection (Y/N)	N	N	N	N	_____
Chlorination (Y/N)	Y	Y	Y	_____	_____
Filtration (Y/N)	Y	Y	Y	_____	_____

Cluster GW-6

Sources Inadequate



Three wells currently provide water for Cluster GW-6, which is owned and operated by Linn-Livingston County PWSD #3. MDNR records indicate wells #1, #3, and #4 are active. Well #2 is inactive due to high sand content and reduced yield. Well #1 is treated for iron bacteria every six to eight weeks during production, which is about four to five months a year. Laredo, a wholesale customer of Linn-Livingston County PWSD #3, closed its groundwater treatment plant due to high iron in 2000. Wheeling, also a wholesale customer, closed its groundwater treatment plant after decades of struggling with declining yield and high iron content as well. A listing of the closed systems within all the clusters can be found in Appendix C.

The current water demands in the cluster are detailed in the following table and total 0.168 MGD of treated water.

Given the history of declining wells and location in glacial deposits, this evaluation has identified Cluster GW-6's sources as inadequate.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-6	Linn-Livingston PWSD #3					0.168		0.107
	Laredo						100%	0.013
	Linneus						100%	0.028
	Wheeling						100%	0.020

Linn-Livingston Co. PWSD #3

PWSS No. 2024350


2 Wells, Livingston County

Prepared by:

Map Update: Jan 22, 2016



Missouri Department of
Natural Resources




Well System

H System Well


SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Feet



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey
(USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Linn-Livingston Co. PWSD #3

PWSS No. 2024350

Livingston County

2 wells

Prepared by:



Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W1	W3
Extended PWS #	2024350101	2024350103
Local Well Name	Well #1, Old Well	Well #3
Well ID #	13831	18093
DGLS ID #	_____	_____
Facility Type	Water District	Water District
Status	Active	Active
Latitude	39.77878	39.77775
Longitude	-93.38288	-93.383722
Location Method	DRG/MAP	GPS
Method Accuracy (ft)	33	98
USGS 7.5 Quadrangle	Wheeling	Wheeling
County	Livingston	Livingston
MoDNR Region	Northeast	Northeast
Date Drilled (year)	1964	2000
Material (C/U)	Unconsolidated	Unconsolidated
Base of Casing Formation	Glacial Deposits	Glacial Deposits
Total Depth Formation	Glacial Deposits	Glacial Deposits
Total Depth	137	131
Ground Elevation (ft)	754	_____
Top Seal	_____	_____
Bottom Seal	_____	_____
Casing Depth (ft)	115	116
Casing Size (in)	12	18
Casing Type	Steel	Steel
Elev. of Casing Top (ft)	_____	_____
Outer Casing Depth (ft)	_____	_____
Outer Casing Size (in)	_____	_____
Screen Length (ft)	15	15
Screen Size (in)	30	_____
Static Water Level (ft)	58	_____
Well Yield (gpm)	225	_____
Head (ft)	_____	_____
Draw Down (ft)	20	21
Pump Test Date (year)	1992	_____
Pump Type	Vertical Turbine	_____
Pump Manufacturer	_____	_____
Pump Depth (ft)	_____	_____
Pump Capacity (gpm)	_____	250
Pump Meter (Y/N)	Y	_____
VOC Detection (Y/N)	N	_____
Nitrate Detection (Y/N)	N	_____
Chlorination (Y/N)	Y	_____
Filtration (Y/N)	Y	_____
GWUDISW (Y/N)	N	_____
Surface Drainage	_____	_____
State Approved(Y/N)	Y	_____
Date Abandoned (year)	_____	_____
Date Plugged (year)	_____	_____

Cluster GW-7

Sources Inadequate



Cluster GW-7 is supplied by two groundwater wells, which are owned and operated by the City of Meadville, Missouri. Well #1 and Well #3 yield approximately 60 gpm each to provide water to the 50 gpm, iron removal, water treatment plant. These two wells are located within 20 feet of each other. The 2015 average daily normal demand was 0.033 MGD serving a population of approximately 450.

Given the location of the wells in glacial deposits, this evaluation has identified Cluster GW-7's sources as inadequate.

Meadville

PWSS No. 2010512


3 Wells, Linn County

Prepared by:

Map Update: Jan 22, 2016



Missouri Department of
Natural Resources




Well System

H System Well


SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Feet



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey
(USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Meadville

PWSS No. 2010512

Linn County

3 wells

Prepared by:



Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W1	W2	W3
Extended PWS #	2010512101	2010512102	2010512103
Local Well Name	Well #1	Well #2	Well #3
Well ID #	14937	14936	14938
DGLS ID #	_____	_____	_____
Facility Type	City	City	City
Status	Active	Emergency	Active
Latitude	39.78458	39.78358	39.78459
Longitude	-93.30058	-93.30152	-93.30045
Location Method	DRG/MAP	DRG/MAP	DRG/MAP
Method Accuracy (ft)	33	33	33
USGS 7.5 Quadrangle	Meadville	Meadville	Meadville
County	Linn	Linn	Linn
MoDNR Region	Northeast	Northeast	Northeast
Date Drilled (year)	1954	1954	1977
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Glacial Deposits	Glacial Deposits	Glacial Deposits
Total Depth Formation	Glacial Deposits	Glacial Deposits	Glacial Deposits
Total Depth	70	68	82
Ground Elevation (ft)	_____	_____	_____
Top Seal	_____	_____	_____
Bottom Seal	_____	_____	_____
Casing Depth (ft)	_____	_____	74
Casing Size (in)	_____	_____	16
Casing Type	Steel	Steel	Steel
Elev. of Casing Top (ft)	_____	_____	_____
Outer Casing Depth (ft)	_____	_____	_____
Outer Casing Size (in)	_____	_____	_____
Screen Length (ft)	_____	_____	10
Screen Size (in)	_____	_____	10
Static Water Level (ft)	_____	_____	43
Well Yield (gpm)	_____	_____	35
Head (ft)	_____	_____	_____
Draw Down (ft)	_____	_____	34
Pump Test Date (year)	_____	_____	1977
Pump Type	Vertical Turbine	_____	Submersible
Pump Manufacturer	_____	_____	_____
Pump Depth (ft)	_____	_____	77
Pump Capacity (gpm)	50	50	40
Pump Meter (Y/N)	Y	_____	Y
VOC Detection (Y/N)	N	N	N
Nitrate Detection (Y/N)	N	N	N
Chlorination (Y/N)	_____	_____	Y
Filtration (Y/N)	Y	_____	Y
GWUDISW (Y/N)	N	_____	N
Surface Drainage	_____	_____	_____
State Approved(Y/N)	_____	_____	Y
Date Abandoned (year)	_____	_____	_____
Date Plugged (year)	_____	_____	_____

Cluster GW-8

Sources Inadequate



Cluster GW-8 is served by six groundwater wells owned and operated by the City of Princeton, Missouri. These wells are documented as being located in the alluvium of the Weldon River. MDNR records indicate eight wells plugged or inactive in the system, detailed in the Well History table below. Given the history of declining wells Cluster GW-8 is identified as having inadequate sources.

Well History				
Well #	Status	Year Drilled	Year Abandoned	Year Plugged
Well # 1	Plugged	1973	-	2009
Well # 1, Old	Plugged	-	1995	1995
Well # 2B	Plugged	1968	-	2002
Well # 3	Inactive	1971	-	-
Well # 5	Plugged	-	-	2002
Well # 7	Plugged	1978	-	2002
Well # 12	Plugged	-	1995	1995
Well # 13	Plugged	-	1995	1995

The Production and Demand table below details the 2015 average consumption of the 0.137 MGD within the cluster.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-8	Princeton					0.137		0.078
	Mercer						100%	0.024
	Mercer County PWSD #1						18%	0.195

Princeton

PWSS No. 2010664

6 Wells, Mercer County


Prepared by:

Map Update: Jan 22, 2016



Missouri Department of
Natural Resources

R24W




Well System

H System Well


SWAP Delineation Boundary

○ 20-year time of travel

○ Half-mile buffer



Miles



SWAP - Source Water Assessment Plan --
<http://drinkingwater.missouri.edu/swap/>
For basemap symbols, see the U.S. Geological Survey (USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MoDNR), no warranty, expressed or implied, is made by MoDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MoDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Princeton

PWSS No. 2010664

Mercer County, sheet 1 of 2

6 wells

Prepared by:

Sheet Update: Jan 25, 2016



Missouri Department of
Natural Resources

Well Number	W3	W8	W9	W10	W11
Extended PWS #	2010664103	2010664108	2010664109	2010664110	2010664111
Local Well Name	Well #2A	Well #8	Well #9	Well #10	Well #11
Well ID #	13680	14544	14543	14546	14545
DGLS ID #	_____	_____	_____	_____	_____
Facility Type	City	City	City	City	City
Status	Active	Active	Active	Active	Active
Date Drilled (year)	1957	1980	1980	1995	_____
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Alluvium	Alluvium	Alluvium	Alluvium	Alluvium
Total Depth Formation	Alluvium	Alluvium	Alluvium	Alluvium	Alluvium
Total Depth	42	37	39	45	44
Ground Elevation (ft)	830	825	825	825	825
Top Seal	_____	_____	_____	_____	Cement Grout
Bottom Seal	_____	_____	_____	_____	Cement Grout
Static Water Level (ft)	12	18	19	_____	18
Well Yield (gpm)	65	90	90	_____	225
Head (ft)	_____	75	75	88	89
Draw Down (ft)	10	11	13	_____	18
VOC Detection (Y/N)	N	N	N	N	N
Nitrate Detection (Y/N)	N	N	N	N	N
Chlorination (Y/N)	Y	Y	Y	Y	_____
Filtration (Y/N)	Y	Y	Y	_____	_____

Princeton

PWSS No. 2010664

Mercer County, sheet 2 of 2

6 wells

Prepared by:



Sheet Update: Jan 25, 2016




Missouri Department of
Natural Resources

Well Number	W14
Extended PWS #	2010664114
Local Well Name	Well #12
Well ID #	17224
DGLS ID #	_____
Facility Type	City
Status	Active
Latitude	40.41783
Longitude	-93.61218
Location Method	GPS
Method Accuracy (ft)	75
USGS 7.5 Quadrangle	Princeton
County	Mercer
MoDNR Region	Northeast
Date Drilled (year)	2004
Material (C/U)	Unconsolidated
Base of Casing Formation	Glacial Deposits
Total Depth Formation	Glacial Deposits
Total Depth	44
Ground Elevation (ft)	825
Top Seal	_____
Bottom Seal	_____
Casing Depth (ft)	41
Casing Size (in)	24
Casing Type	_____
Elev. of Casing Top (ft)	846.5
Outer Casing Depth (ft)	31
Outer Casing Size (in)	48
Screen Length (ft)	10
Screen Size (in)	24
Static Water Level (ft)	19
Well Yield (gpm)	_____
Head (ft)	89
Draw Down (ft)	_____
Pump Test Date (year)	_____
Pump Type	Submersible
Pump Manufacturer	_____
Pump Depth (ft)	_____
Pump Capacity (gpm)	150
Pump Meter (Y/N)	Y
VOC Detection (Y/N)	_____
Nitrate Detection (Y/N)	_____
Chlorination (Y/N)	_____
Filtration (Y/N)	_____
GWUDISW (Y/N)	_____
Surface Drainage	_____
State Approved(Y/N)	_____
Date Abandoned (year)	_____
Date Plugged (year)	_____

Cluster GW-9

Sources adequate




Cluster GW-9 is supplied by two groundwater wells, which are owned and operated by the City of Salisbury, Missouri. Well #1 has high ammonia content and is not actively used. Well #2 and Well #3 are alternated in use having a routine yield of approximately 300 gpm in the alluvium of the Chariton River. The 2015 average daily normal demand was 0.175 MGD which was produced by the iron removal water treatment plant (MDNR 2016).



Given the proximity to the Chariton River and no known history of declining yield wells, Cluster GW-9 is identified as having adequate sources.



Salisbury

3 Wells, Chariton County
 PWSS No. 2010722

Prepared by:  Missouri Department of Natural Resources
 Map Update: Jan 22, 2016



-  Half-mile buffer
-  20-year time of travel
- SWAP Delineation Boundary**
- H** System Well
- Well System**



SWAP - Source Water Assessment Plan --
 http://drinkingwater.missouri.edu/swap/
 For basemap symbols, see the U.S. Geological Survey
 (USGS) publication: Topographic Map Symbols.

Although all data in this dataset have been used by the Missouri Department of Natural Resources (MDNR), no warranty, expressed or implied, is made by MDNR as to the accuracy of the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by MDNR in the use of these data or related materials. This map is subject to change as additional information is acquired. Additional information at: <http://drinkingwater.missouri.edu>.

Salisbury

PWSS No. 2010722

Chariton County

3 wells

Prepared by:



Sheet Update: Jan 25, 2016



Missouri Department of
Natural Resources

Well Number	W1	W2	W3
Extended PWS #	2010722101	2010722102	2010722103
Local Well Name	Well #1	Well #2	Well #3
Well ID #	14628	14630	14629
DGLS ID #	_____	_____	_____
Facility Type	City	City	City
Status	Emergency	Active	Active
Latitude	39.42475	39.42175	39.422472
Longitude	-92.874694	-92.883694	-92.880778
Location Method	GPS	GPS	GPS
Method Accuracy (ft)	100	100	100
USGS 7.5 Quadrangle	Salisbury	Keytesville	Keytesville
County	Chariton	Chariton	Chariton
MoDNR Region	Northeast	Northeast	Northeast
Date Drilled (year)	1980	1981	1980
Material (C/U)	Unconsolidated	Unconsolidated	Unconsolidated
Base of Casing Formation	Alluvium	Alluvium	Alluvium
Total Depth Formation	Alluvium	Alluvium	Alluvium
Total Depth	68	60	70
Ground Elevation (ft)	738	663	613
Top Seal	_____	_____	_____
Bottom Seal	_____	_____	_____
Casing Depth (ft)	68	60	70
Casing Size (in)	24	24	24
Casing Type	Steel	Steel	Steel
Elev. of Casing Top (ft)	645	648	645
Outer Casing Depth (ft)	_____	_____	_____
Outer Casing Size (in)	_____	_____	_____
Screen Length (ft)	12	12	12
Screen Size (in)	24	24	24
Static Water Level (ft)	30	28	30
Well Yield (gpm)	250	250	250
Head (ft)	42	42	44
Draw Down (ft)	36	35	38
Pump Test Date (year)	1980	1981	1980
Pump Type	Vertical Turbine	Vertical Turbine	Vertical Turbine
Pump Manufacturer	_____	_____	_____
Pump Depth (ft)	55	55	55
Pump Capacity (gpm)	600	600	600
Pump Meter (Y/N)	Y	Y	Y
VOC Detection (Y/N)	N	N	N
Nitrate Detection (Y/N)	N	N	N
Chlorination (Y/N)	Y	Y	Y
Filtration (Y/N)	Y	Y	Y
GWUDISW (Y/N)	N	N	N
Surface Drainage	_____	_____	_____
State Approved(Y/N)	Y	Y	Y
Date Abandoned (year)	_____	_____	_____
Date Plugged (year)	_____	_____	_____

Summary of Groundwater Cluster Evaluations

Approximately 39 percent of Missouri's population is served by groundwater sources (MDNR 2015). In 2015, the groundwater sources of north-central Missouri, accounted for approximately 15.5 percent (2.122 MGD) of the total (13.723 MGD) treated drinking water produced in the 10-county study area. This percentage supports the claims of geologists, well drillers, engineers, and planners that there is a pronounced lack of quality, plentiful groundwater in north-central Missouri. If quality, plentiful groundwater were available in the region, it would be reasonable to assume that comparing the percentage of the total water produced would be similar to that of the state. Additionally, it would be reasonable to assume that there would be more than nine groundwater systems in the four of 10 counties within the region that utilize groundwater as a source of raw water.

Of the 2.122 MGD of groundwater produced in the region, Chillicothe Municipal Utilities (Cluster GW-3) provided nearly 1.30 MGD or 61.3 percent of the total average daily demand supplied by groundwater. This large volume producer also comports with geologic analysis which states: "In general, the most favorable alluvial deposits appear to be those of the lower parts of the Grand and Chariton rivers." (MDNR 1997) The other eight groundwater clusters provided a combined total average of 0.822 MGD. A total of four of the 9 groundwater systems in the study region are located within the alluvium of the Grand and Chariton rivers. They include Chillicothe, Missouri American-Brunswick, Keytesville, and Salisbury.

Other groundwater systems in the study region include: Livingston County PWSD #2, Princeton, Linn County Consolidated PWSD #1, Meadville, and Linn-Livingston PWSD #3 and are located in pre-glacial deposits or smaller stream modern alluvium. The fact that these systems have found enough water, after extensive test hole drilling, to supply their current demand is also explained by Miller as, "pre-glacial alluvial deposits are, unfortunately, limited in areal extent, and are found in rather narrow linear trends, much the same as modern alluvial valleys" (MDNR 1997).

An example of a public water system struggling to find quality and plentiful water is Linn County Consolidated PWSD #1 (Cluster GW-5). A letter explaining the unsuccessful findings from Brotcke Well and Pump from 2003 is included in Appendix B. The embedded map from that letter details the locations of over 30 drilled test wells from 1966-2003. Because of the low average daily demand of 0.085 MGD, the cluster has been able to meet demand with the existing wells, although system staff indicated that Well #2 is virtually unusable due to excessive iron content.

Wells in this region are in decline and losing yield. This has resulted in the closing of 16 groundwater treatment facilities since 1980 and numerous closed/abandoned wells of the current groundwater systems. Appendix C lists the closed systems in the region and Appendix F contains a table of closed wells for active groundwater systems.

Under current demand conditions and the cumulative history of the region, this evaluation has determined that three of the nine ground water clusters might provide an adequate source of dependable quality water for the future. These systems are GW-2 (MO American- Brunswick), GW-3 (Chillicothe Municipal Utilities), and GW-9 (Salisbury). These three systems provided 1.559 MGD (or 73.5 percent) of treated ground water within the study region in 2015. The remaining 0.563 MGD, of treated groundwater, was provided by six systems, ranging in production from 0.033 MGD to 0.168 MGD. The corresponding raw water demand of the six inadequate source clusters, estimating 10 percent treatment losses, totals 0.619 MGD.

A complete listing of the Groundwater Cluster Production and Demand Table from 2015 is located in Appendix K. The impact of inadequate cluster water sources could result in the complete depletion of water in six of nine the existing clusters. Figure 10, below, shows clusters with inadequate sources in red and those with adequate sources, in green. Each segment of the pie corresponds to a groundwater producer within the 10-county region. The size of each segment is proportionate to the average daily demand produced by each system, shown as the value at the end of the labels in MGD.





Figure 10: Groundwater Source Cluster Summary

Overview of Out-of-Region Cluster Evaluations

A total of three out-of-region suppliers provided 1.035 MGD of treated water within the 10-county study region in 2015. Both Rathbun Regional Water Association (OR-1) and Clarence Cannon Wholesale Water Commission (OR-2) provide treated surface water via direct wholesale connections. Livingston County PWS #4 (OR-3) serves customers and is based within the region, but the groundwater wells are located in adjacent Daviess County. Wholesale customers of the Livingston County PWS#4 are located in Daviess and Caldwell counties, neither of which are within the study region.

Given that the evaluation herein is for sources within the 10-county region of study, analysis of sources outside the region is irrelevant, except that there are communities within the study region depend on those sources for water daily. The underlying assumption is that out-of-region sources will be able to provide the current quantity of water into the future.

Figure 11, below, shows the proximity of the out-of-region surface water sources for OR-1 and OR-2 to the 10-county region.




Version: 2.14.5-ES&M Path: J:\CARES Quantum Projects\Missouri Water Supply 2.0\of&gs

The following out-of-region cluster reports provide information about the systems dependent on the sources from outside of the region. Specific information in regard to drought resistance of those specific sources would have required extensive understanding, cooperation, and research to analyze each regional supply, their demands, and effecting conditions. This was additional research was beyond the scope of this evaluation.

Out-of-Region Reports OR-1 to OR-3

Cluster OR-1

Source Inadequate



The U.S. Army Corps of Engineers built Rathbun Lake in 1970 as a flood control, recreation, and water supply reservoir. Initially 6,680 acre-feet of the total drinking water allocation of 15,000 acre-feet, was contracted to the Rathbun Regional Water Association who treats the surface water supply. The remaining 8,320 acre-feet were designated as a first right of refusal for Rathbun Regional Water Association, who supplies treated water to over 14 Iowa counties and four Missouri counties.

An important note about OR-1 is that Rathbun Regional Water Association is located in Iowa. Water conveyance across state lines is explicitly listed in 455B.266 Priority Allocation which states:

"2. Notwithstanding a person's possession of a permit or the person's use of water being a nonregulated use, the department may suspend or restrict usage of water by category of use on a local or statewide basis in the following order:

- a. Water conveyed across state boundaries.
- b. Water used primarily for recreational or aesthetic purposes.
- c. Uses of water for the irrigation of any general crop.
- d. Uses of water for the irrigation of any specialty crop.
- e. Uses of water for manufacturing or other industrial processes.
- f. Uses of water for generation of electrical power for public consumption.
- g. Uses of water for livestock production.
- h. Uses of water for human consumption and sanitation supplied by rural water districts, municipal water systems, or other public water supplies. (Iowa 2016)"

Mr. John Glenn of Rathbun Regional Water Association spoke about the drought of 2012 in an April 2013 article of Wallaces Farmer, stating, "RRWA's water treatment plant averaged 7.5 million gallons per day last summer with the peak day producing 10.2 mgd, quite a feat considering the plant's designed capacity is only 8 mgd. Peak demand is strongly tied to livestock use. "Livestock use accounted for up to one-half of RRWA peak water

demand last summer," says Glenn. "More than 70 new service connections for livestock were installed in 2012, up from the five-year average of 20 per year (Chester 2013)."

At that time a second water treatment facility was under construction and Glenn was quoted again in the December 2013 Wallace Farmer, saying: "We are now able to supply more than 14 million gallons of water daily to customers, almost double our capacity before this project," says Glenn. "This additional supply of drinking water is essential for RRWA to be able to support continued economic and community development efforts across our service territory (Chester 2013b)."

From that same article "Marty Braster, RRWA environmental specialist, says based on previous growth trends and water usage per meter, RRWA is now well prepared to meet the projected demand of peak daily use of 14 million gallons a day by 2035.(Chester 2013b)."

In 2015, Rathbun Regional Water Association provided 0.557 MGD of treated water, or approximately 47 percent of the total 1.175 out-of-region water. Given following list of factors it is reasonable to categorize OR-1 as an inadequate source for Missouri communities:

- Peak demands due to drought were 36 percent above normal demand in 2012
- Rathbun is part of community development and economic growth to over 14 counties in Iowa
- Availability of water during extreme drought depends upon choices made by another state
- Restriction of water conveyance over a state boundary is the first legal priority in allocation


The impact of this inadequate source categorization is that nearly eight second and third tier systems will be without water, at current demand totaling 0.557 MGD. Therefore, Cluster OR-1 is identified as an inadequate source.

The Production and Demand table below details the Missouri communities dependent upon Rathbun for treated water. Note that Adair PWSD #1 is a third tier system to Rathbun and receives 0.25 percent of its total 0.463 MGD (or 0.001 MGD) from Rathbun. The systems listed below Adair PWSD#1 in this table do not receive water from Rathbun and were not included in the Cluster OR-1 map above.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
OR-1	Rathbun					0.557		
	Lancaster						100%	0.065
	Glenwood						100%	0.013
	Mercer County PWSD #1						95%	0.160
	Putnam County PWSD #1						32%	0.207
	Lake Thunderhead HOA						100%	0.021
	Schuyler County CPWSD #1						100%	0.266
	Downing						100%	0.026
	Adair PWSD #1						0.25%	0.463
	Brashear						100%	0.014
	LaPlata						100%	0.079
	Novinger						100%	0.026
	Macon County PWSD #1						1%	0.014
	Callao						100%	0.024
	Clarence						100%	0.065
Elmer						100%	0.005	

Cluster OR-2

Source Adequate



Clarence Cannon Wholesale Water Commission provides treated surface water from Mark Twain Lake in Ralls County Missouri. Mark Twain was constructed by the U.S. Army Corps of Engineers in 1983 on the Salt River to provide flood control, hydroelectricity, public water supply, recreation and navigation. Based on a three-party contract between the U.S. Army Corps of Engineers, the state of Missouri, and the Clarence Cannon Wholesale Water Commission, 20,000 acre-feet of the nearly 400,000 acre-feet within the beneficial use pool, was designated for drinking water supply.

In 2015, the Clarence Cannon Wholesale Water Commission provided 0.278 MGD to the 10-county study region, as detailed in the Production and Demand table below. Cluster OR-2 has an adequate source as determined by this evaluation.

The following excerpt is from the Mark Twain Lake Master Plan 2015 (USACE 2015):


“Water Treatment Plant, Clarence Cannon Wholesale Water Commission. This regional water treatment plant is located four miles west of Florida, Missouri off of State Highway U. This facility was constructed in 1991 and 1992. The production and sale of water to members began on June 16, 1992. The Clarence Cannon Wholesale Water Commission (CCWWC) entered into a three party contract with the US Army Corps of Engineers and the State of Missouri to purchase water storage space in Mark Twain Lake. The contract allows for removal of a maximum of 16 million gallons of raw water per day with an allowance for a failure rate of 2 years out of every 100 years for not being able to supply the full 16 million gallons per day. The CCWWC owns the rights to 5.0 million gallons of storage space, while the remaining 11.0 million gallons of water per day are available to them through contract with the State of Missouri. The CCWWC facilities consists of a 4.5 million gallons per day surface water treatment plant, which uses

flocculation, sedimentation, and filtration to purify raw water to acceptable standards for drinking purposes. In addition to the main facilities, the infrastructure consists of 325 miles of transmission mains, four booster pumping stations, a raw water intake structure located on the North Fork Branch of Mark Twain Lake, and daily storage space for 4.5 million gallons of drinking water. The CCWWC currently serves potable water for use by 15 cities, 14 counties, 9 water districts and 72,942 people. Expansion is underway to serve additional customers."

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
OR-2	Clarence Cannon					0.278		
		Macon County PWSD #1					18%	1.523
			Callao				100%	0.024
			Clarence				100%	0.080
			Elmer				100%	0.005

Cluster OR-3

Sources Adequate



Livingston County PWSD #4 provides groundwater via three wells located in Daviess County, Missouri. Daviess County is not within the 10-county study region; therefore, this cluster is considered out-of-region. The water district serves customers in both Livingston and Daviess counties, and it also wholesales water to customers in Caldwell and Daviess counties. MDNR well data show that two glacial alluvial wells drilled in the 1970s yielded approximately 200 gpm each of water for the system. In 2010, a new well was located in the nearby Grand River alluvium and is recorded to have a yield of 500 gpm. This new source brought new customers in 2014 when Breckenridge, Missouri and Jamesport, Missouri chose to close their surface water treatment plants. The Production and Demand table below details the 0.340 MGD of treated water produced in 2015 and the communities reliant upon it. Only the 0.200 MGD of the produced water is considered consumption by the district customers within the 10 county region. The other supply goes to communities outside the region and is not included in the summary calculations. Cluster OR-3 is identified as an adequate source given its history and reliability.

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
	Livingston Co. PWSD 4					0.340		0.200
	Jamesport						100%	0.040
	Daviess PWSD #2						40%	0.100
	Jameson						100%	0.006
	Breckenridge						100%	0.001
	Hamilton						22%	0.050
	Caldwell Co. PWSD #2						100%	

Summary of Out-of-Region Cluster Evaluations

An important note about OR-1 is that Rathbun Regional Water Association is located in Iowa and water conveyance across state lines is explicitly listed in Iowa Administrative Code (IAC) 567-subrule 52.10(2) which states:

“2. Notwithstanding a person's possession of a permit or the person's use of water being a nonregulated use, the department may suspend or restrict usage of water by category of use on a local or statewide basis in the following order: a. Water conveyed across state boundaries.”

Rathbun Regional Water Association provided 0.557 MGD of treated water, or approximately 47 percent of the total 1.035 MGD out-of-region water in 2015. Given that the availability of water during extreme drought depends upon choices made by another state, it is reasonable to categorize OR-1 as an inadequate source. This is explained in the Cluster OR-1 report. The impact of this categorization is that nearly eight second and third-tier systems will be without water, at current demand totaling 0.557 MGD.

A complete listing of the Out-of-Region System Cluster Production & Demand Table from 2015 is located in Appendix L. Figure 12, below, shows clusters with inadequate sources in red and those with adequate sources in green. Each segment of the pie corresponds to a water producer from outside the 10-county region. The size of each segment is proportionate to the average daily demand supplied by each system to the region, shown as the value at the end of the labels in MGD.




Figure 12: Out-of-Region Cluster Status

Summary of Findings

The evaluation, herein, included surface water and groundwater sources serving communities the in the north-central Missouri 10-county region of study including Adair, Chariton, Grundy, Linn, Livingston, Macon, Mercer, Putnam, Schuyler, and Sullivan counties. By evaluating clusters of drinking water providers and their customers, the determination of sufficient, reliable raw water for the 10 county region, as a whole, was possible. The analysis was based upon the following assumptions:

- Current daily raw water demands remain constant
- DOR recharge conditions
- 50 years of sediment loading for surface water systems
- Water sources are sized according to current MDNR design requirements
- Geologic and hydrogeological evidence
- Local history and information specific to water supply

The clusters were divided into three subsets, surface water clusters (SW-1 through SW-6), groundwater clusters (GW-1 through GW-9) and out-of-region clusters (OR-1 through OR-3). These 18 clusters, comprised of 19 water producers provided 13.723 MGD of treated water within the 10-county region in 2015 (this quantity does not include impending demand from Kraft-Heinz). Figure 13, below, summarizes the production from the individual cluster reports by out-of-region and source water type.





Figure 13: 2015 Water Provided to 10-county region

Figure 14, summarizes the type of source water in respect to the total amount of treated water produced for the 10-county region in 2015.



Figure 14: Total Water Produced in 10-county region in 2015.

Figure 15, below, details the current location and source water type of the active public water systems in the 10-county region of study. Note that out-of-region sources are not depicted on this figure. Additionally, six of the 10-counties have one source of water and Schuyler County did not have any PWSs produce water in 2015.



QGIS Version: 2.14.5-Essen Path: J:/CARES/Quantum Projects/Missouri Water Supply 2.8noF.qgs

Figure 15: Active Public Drinking Water Treatment Facilities in 10 county region.

As noted in Figure 4 and Appendix C, 28 systems have ceased water treatment activities in the 10-county region since 1980. This regionalization or aggregation of systems is because of reduced source water yield, increasing water quality standards, and expense of maintaining a degrading facility. The reduction in number of water suppliers has placed a strain on more reliable sources within the region, pushing some past a reliability threshold during DOR conditions.

The surface water cluster evaluation determined that five of the six clusters had inadequate sources during a DOR. When these inadequate sources dry up during the drought, they are no longer able to provide any water, until a rainfall event occurs which may allow them to supply a small quantity of water. The cumulative total of treated water demand for these four clusters, given 2015 demands, is 8.406 MGD. This number includes the 0.350 MGD impending demand of the Kraft-Heinz expansion.

The groundwater cluster evaluation determined that 6 of the 9 clusters had inadequate sources based on historical data of wells in the region. In the event of a DOR, their capacity to produce water can be expected to decrease, because they are all based on shallow aquifers. The extent of this decrease is unknown, but once such systems run short of water, they will be inclined to purchase water elsewhere and once they start doing that, it is not likely in their interest to continue producing water once they are connected to larger producers. The cumulative total of treated water demand for these six clusters, given 2015 normal demands, is 0.563 MGD.

The out-of-region cluster evaluation determined that one of the three clusters (a surface water source) had an inadequate source given a dependability question in regards to inter-state conveyance. The total of treated water demand for this cluster is 0.557 MGD.

The cumulative total of inadequate sources serving the 10-county region, based on current treated water normal demand, is 9.526 MGD. The cumulative total was calculated by summing the 2015 treated water demand from those systems determined to have a deficit during the evaluation (including 0.35 MGD from the Kraft-Heinz expansion). Converting this total to raw water requires adding 10 percent or 0.953 MGD, which increases the total regional deficit to 10.479 MGD, based on current demands. Figure 16, below, displays the summary of information from the cluster evaluation sections and displays all of the evaluated clusters proportional to one another. This Regional Source Water Cluster Status graph represents all 18 clusters and 19 water producers in the region.

2015 Treated Water Demand Data and used in Figure 16.

2015 Treated Water Demand Data	Demand on Inadequate Sources (MGD)	Demand on Adequate Sources (MGD)	Total Treated Water Demand in 2015 (MGD)
Surface Water	8.623	2.778	11.401
Groundwater	0.563	1.759	2.322
Total	9.186	4.537	13.723

In the 10-county region of study 13 of the 18 clusters, or 14 of the 19 water producers, have inadequate sources of raw water supply. These 13 producers were responsible for 67 percent (9.186 MGD of the 13.723 MGD) of the water supplied to the region in 2015.

In Figure 16, the Surface Water Cluster Status graphic summarizes the five clusters or six producers who have inadequate sources of raw water supply. Overall these producers were responsible for 63 percent (8.623 MGD of the 13.723 MGD) of the total water supplied to the region. In Figure 16, the Groundwater Cluster Status graphic summarizes the six of the 10 clusters which have inadequate sources of raw water supply. Overall these producers were responsible for 13 percent (1.759 MGD of the 13.723 MGD) of the total water supplied to the region.





Figure 16: Summary of Cluster Status and Percent Production

Figure 17 displays on a map the evaluated clusters and summarizes the determination of their sources as adequate or inadequate.



QGIS Version: 2.14.5-Essen Path: J:/CARES/Quantum Projects/Missouri Water Supply 2.8noF.qgs

Figure 17: Status of Public Drinking Water Treatment Systems in 10-county region.

Conclusion

There is a well-documented lack of adequate source water in north-central Missouri. Communities that developed sources, for their own current and future use, are rapidly becoming unintended regional systems as neighboring communities sources continue to deteriorate. The neighboring systems with inadequate sources become dependent upon and place unplanned burden on adequate sources. The result, as shown by the analysis herein, is a 10-county region of north-central Missouri now at risk of running out of water during severe drought conditions. The risk of insufficient water has an impact on community and economic growth.

If a new source(s) is not developed prior to another severe drought event, like that experienced in the 1950s, there will be significant and detrimental impacts made to the communities that call north-central Missouri home. This rural region of Missouri helps provide agri-goods to not only Missouri, but also to surrounding states; therefore, the threat of a no water scenario for 63 percent of users within the region has more broad effect. The impact of wide-spread water shortages on the health and safety of the local population is indisputably negative.

Correcting the 9.186 MGD deficit of inadequate sources by developing new sources will help secure the status quo. New water sources will need to be sized to allow for the support of regional economic growth of existing businesses, as well as for new businesses. Former MDNR Director, Sarah Parker-Pauley, is quoted saying, "Where there is water, there are communities. This is no coincidence" (Pauley 2016).

Bibliography


- Allstate Consultants. Preliminary Engineering Report and Feasibility Analyses for Water System Source Improvements. Columbia: Allstate Consultants LLC, 2013.
- Burns & McDonnell. "Water System Master Plan." 2003.
- Chester, Kathleen. "farmprogress.com." April 2013. Wallaces Farmer.
<<http://magissues.farmprogress.com/wal/WF04Apr13/wal052.pdf> >.
- . "Farmprogress.com." December 2013. Wallaces Farmer.
<<http://magissues.farmprogress.com/wal/WF12Dec13/wal074.pdf> >.
- DNR, Iowa. Environmental Protection. 2016. August 2016. <<http://www.iowadnr.gov/Environmental-Protection/Water-Quality/Water-Supply-Engineering/Water-Quantity>>.
- Hunsicker, Jason. "Progress Edition 2016: Kraft Heinz \$250 million expansion a 'miracle' for Kirksville." Kirksville Daily Express 28 July 2016.
- Iowa, State of. "567.52.10 Priority allocation restrictions." Iowa Administrative Code. n.d.
- McMillen, Fuller and. Water Possibilities from the Glacial Drift of Putnam County. WR-4. Rolla: Missouri Geological Survey and Water Resources, 1956.
- MDNR. "Annual Compliance Report of Missouri Public Water Systems Pub. 2662." 2015.
- . Census of Missouri Public Water Systems. Jefferson City, MO: Missouri Department of Natural Resources, 2014.
- . Drinking Water Watch. Jefferson City, 2016. Database.
- . "Hydrologic Extremes in Missouri: Flood and Drought, Missouri State Water Plan Series - Volume V." 1997. WR-49. August 2016. <<http://dnr.mo.gov/pubs/WR49.pdf>>.
- . "Minimum Standards for Missouri Public Water Supply Systems." December 2013.
- . Missouri Public Drinking Water Website. August 2016. Database.
<<http://drinkingwater.missouri.edu/gisdata/index.html>>.
- . "Missouri State Water Plan Series Vol. III, Groundwater Resources of Missouri." WR-46. 1997.
- . "Missouri Water Supply Study." 2013.
- . Surface Water Resources of Missouri. Rolla: Missouri Department of Natural Resources, 1995.
- . "Surface Water Resources of Missouri, Missouri State Water Plan Series - Volume I." 122. WR-45. August 2016. <<http://dnr.mo.gov/pubs/WR45.pdf>>.
- . Topics in Water Use: Northeastern Missouri. WR-59. Rolla: Division of Geology and Land Survey, 1998.
- . Water Use Study of North Central Missouri Regional Water Commission. Macon: Missouri Department of Natural Resources, 2004.
- . WIMS Search. n.d. August 2016. <<https://dnr.mo.gov/mowells/wimsSearchLanding.do>>.
- MDNR, E. Baker. "List of Closed PWS's in North Central Missouri Since 1980." Memo, December 2015.
- MSDIS. MSDIS Data List by Theme. Accessed 2015. <<http://msdis.missouri.edu/data/themelist.html#>>.

- Office of Missouri Governor Jeremiah W. [Jay] Nixon. "The Drought of 2012 - Missouri Recognizes, Responds, Recharges." February 2013. Missouri Department of Natural Resources.
<<http://dnr.mo.gov/pubs/docs/TheDroughtOf2012.pdf>>.
- Others, Fuller and. Water Possibilities from the Glacial Drift of Chariton County. WR-12. Rolla: Missouri Geological Survey and Water Resources, 1957.
- . Water Possibilities from the Glacial Drift of Grundy County. WR-1. Rolla: Missouri Geological Survey and Water Resources, 1956.
- . Water Possibilities from the Glacial Drift of Linn County. WR-11. Rolla: Missouri Geological Survey and Water Resources, 1957.
- . Water Possibilities from the Glacial Drift of Livingston County. WR-6. Rolla: Missouri Geological Survey and Water Resources, 1956.
- . Water Possibilities from the Glacial Drift of Mercer County. WR-2. Rolla: Missouri Geological Survey and Water Resources, 1956.
- . Water Possibilities from the Glacial Drift of Sullivan County. WR-10. Rolla: Missouri Geological Survey and Water Resources, 1957.
- Pauley, Sara. "Emerging Water Policy Issues." 2016.
- QGIS. "Quantum GIS Open Source Software." Version 2.4.0-Chugiak. <<http://qgis.org/en/site/index.html>>.
- U. S. Army Corps of Engineers. 2015. usace.army.mil.
<http://www.mvs.usace.army.mil/portals/54/docs/recreation/marktwain/Mark_Twain_Lake_MasterPlan_2015_All.pdf>.
- U.S. Census Bureau, Housing and Household Economic Statistics Division. census.gov. n.d. August 2016.
<<https://www.census.gov/hhes/www/housing/census/historic/plumbing.html>>.
- USGS. Ground Water Atlas of the United States - Kansas, Missouri, and Nebraska. 1997.
<http://pubs.usgs.gov/ha/ha730/ch_d/index.html>.

Appendices

- A. Regional Map
- B. Letter from Well Driller
- C. Listing of Closed Systems
- D. Map of Closed Systems
- E. Map of Treatment Facilities
- F. Table of Closed Wells
- G. Surface Water Supply Table
- H. Stream Low Flow Table
- I. Treatment Plant Status
- J. Surface Water Cluster Production & Demand Table
- K. Groundwater Cluster Production & Demand Table
- L. Out-of-Region Cluster Production & Demand Table

A. Regional Map



B. Letter from Well Driller



November 25, 2003

Mr. Don Miller
Linn County PWSD No.1
PO Box 111
Purdin, Missouri 64674

RE: Hydrologic Study

Dear Mr. Miller:

Brotcke Well & Pump is performing a Hydrologic Engineering Study for Linn County CPWSD No. 1. The purpose of the Engineering Study is to locate a well that will have a safe yield of 50 GPM or more. Eleven test holes were completed in this phase of the investigation. They are located along Locust Creek. Presented on the attached map are the locations of the eleven TH. They were located with a hand held GPS device. Therefore their location is approximate. Also presented is our interpretation of the location of previous test-holes. The location and results were obtained from your files.

During test hole drilling soil samples were obtained during the performance of the Standard Penetration Test. This procedure uses a 2-inch split-spoon sampler. Representative samples from the split spoon were placed in glass jars and returned to our laboratory, where the samples were used to edit the Field Boring Logs. Copies of the Boring Logs are enclosed.

We don't feel a suitable formation for a well to produce at least 50 GPM has been encountered. The best TH was TH-9-03. This site at best would be equivalent to your Well No. 3. We do not feel a sustainable 50 GPM well can be constructed at this location.

A summary of previous exploration and current test holes are presented on the enclosed attachment. Where we had ground elevation, the bottom of the aquifer elevation is presented. We understand your best well is located at TH-3-97. As shown, the bottom of the aquifer is about elevation 10 feet. This compares favorably with the Well No. 1 which is at TH-1-66, the bottom elevation is 12 feet. Because of the accuracy in this type work, this elevation should be considered equal. As indicated, the locations are shown on the enclosed site sketch.

After reviewing the TH completed during this phase of study and previous work, we suggest additional exploration be performed. One area which has never been explored is West of Locust Creek. Test hole 4-89 was very poor, but it may be beneficial to explore both North and South of that location.

Mr. Don Miller
Linn County CPWSD No. 1
Page 2

A review of the other bottom elevations show all others are about 10 feet to 20 feet higher than the two best Wells, No. 1 and 4. Both are located near the existing water plant. Test Hole 2-97 shows potential for this deeper aquifer. The approximate location is shown on the site map. The test hole report shows 70 feet to the bottom of the aquifer. Depending on the ground elevation, the bottom could be at an elevation in the 10-foot neighborhood.


We recommend that a series of test holes be performed along a line North-South through 2-97. The bedrock valley is apparently very narrow and the TH should be closely spaced to gain the best chance of intersecting the deepest part of the valley.

Brotcke Well & Pump has enjoyed providing these water supply services for the Linn County CPWSD No. 1. For your records we have enclosed the following:

- Field Boring Logs on the eleven test holes.
- Location sketch.
- Test hole summary.

If you have any questions, please do not hesitate to contact us.

Very truly yours,
BROTCKE WELL & PUMP INC.



Mike Thompson
Project Manager

MT/lmv
Enclosure

G:\DIR\Mike\Letters 03\Linn-Miller 11-24-03.doc



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-1-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-20-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	24	SILTY CLAY				
		S-1:	SPT	5-6.5	12"	2-3-4
		S-2: with some fine sand	SPT	16-11.5	14"	2-5-5
		S-3: fine sand layer	SPT	15-16.5	18"	1-3-3
		S-4: dark brown	SPT	20-21.5	16"	1-2-4
		S-5: gray	SPT	22.5-24	14"	1-2-3
24	32	FINE TO MEDIUM SAND				
		S-6:	SPT	25-26.5	12"	2-6-7
		S-7: with some coarse sand and few gravels	SPT	27.5-29	6"	9-6-14
		S-8: with some coarse sand and gravels	SPT	30-31.5	12"	6-15-16
32	38	CLAY/SHALE; gray				
		S-9:	SPT	32.5-34	5"	4-7-12
		S-10	SPT	35-36.5	5"	12-50-Refusal
		S-11:	SPT	37.5-39	5"	Refusal
	38	BOTTOM OF HOLE				

WATER LEVEL OBSERVATIONS			NOTES	Piezometer Installed <input type="checkbox"/> YES <input type="checkbox"/> NO
DURING DRILLING	_____	FT.		Depth _____ Ft.
AT COMPLETION	_____	FT.		39° 58.73N
AFTER _____	HRS _____	FT.		093° 12.18W
AFTER _____	HRS _____	FT.		
AFTER _____	HRS _____	FT.		



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-02-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-21-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	22	SILTY FINE SAND; brown				
		S-1:	SPT	5-6.5	14"	1-2-2
		S-2:	SPT	10-11.5	16"	1-2-2
		S-3: with some clay	SPT	15-16.5	16"	1-1-2
		S-4: Silty Fine Sand to Med. Sand with clay layer	SPT	18.5-20	10"	2-3-4
22	25	SANDY GRAY CLAY	SPT	23.5-25	10"	1-0-4
		S-5:				
25	35	FINE TO MEDIUM SAND				
		S-6: with coarse sand and trace gravel	SPT	28.5-30	6"	2-5-5
		S-7: with trace gravel and clay	SPT	33.5-35	8"	3-8-10
35	40	SHALE/CLAY				
		S-8:	SPT	38.5-40	12"	11-27-34
	40	BOTTOM OF HOLE				
		Drilled Through Some Wood @ 20' ±				

WATER LEVEL OBSERVATIONS			NOTES	Piezometer Installed	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO
DURING DRILLING	_____	FT.			Depth	_____
AT COMPLETION	_____	FT.			39°	58.71N
AFTER _____ HRS	_____	FT.			093°	12.22W
AFTER _____ HRS	_____	FT.				
AFTER _____ HRS	_____	FT.				



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-03-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-21-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	11	SILTY CLAY; brown				
		S-1:	SPT	5-6.5	14"	2-1-1
		S-2: with fine sand	SPT	10-11.5	14"	2-1-1
11	28.5	FINE SAND				
		S-3:	SPT	15-16.5	14"	2-3-3
		S-4:	SPT	18.5-20	6"	1-2-2
		S-5: with some medium sand and Clay Layer	SPT	23.5-25	8"	1-1-2
		S-6: with some medium sand, Small Clay Layer @ 28.5	SPT	28.5-30	6"	3-6-7
28.5	40	SHALE/CLAY				
		S-7:	SPT	33.5-35	6"	7-11-11
		S-8:	SPT	38.5-40	10"	22-Refusal
	40	BOTTOM OF HOLE				
		@				

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-04-03

Project LINN CO. PWSO #1

Job No. 03286

Date 10-22-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	20	SILTY FINE SAND				
		S-1:	SPT	5-6.5	14"	3-4-4
		S-2:	SPT	10-11.5	16"	1-3-3
		S-3: with medium sand	SPT	15-16.5	12"	1-2-2
		S-4: with some clay	SPT	18.5-20	8"	1-1-1
20	30	FINE TO MEDIUM SAND				
		S-5:	SPT	23.5-25	10"	1-5-6
		S-6:	SPT	28.5-30	10"	2-4-4
30	35	SHALE/CLAY				
		S-7:	SPT	33.5-35	14"	12-24-Refusal
	35	BOTTOM OF HOLE				

WATER LEVEL OBSERVATIONS		NOTES
DURING DRILLING	_____ FT.	
AT COMPLETION	_____ FT.	
AFTER _____ HRS	_____ FT.	
AFTER _____ HRS	_____ FT.	
AFTER _____ HRS	_____ FT.	



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-05-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-22-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	11	CLAY				
		S-1:	SPT	5-6.5	14"	1-1-2
		S-2: with silty fine sand	SPT	10-11.5	16"	2-1-1
11	34	FINE TO MEDIUM SAND				
		S-3:	SPT	15-16.5	16"	1-1-2
		S-4: with trace silt	SPT	18.5-20	8"	1-1-1
		S-5: with coarse sand	SPT	23.5-25	5"	2-3-4
		S-6: with some coarse Sand, 2" Clay Layer	SPT	28.5-30	12"	4-4-7
34	35	SHALE/CLAY				
		S-7:	SPT	33.5-35	10"	8-22-REFUSAL
	35	BOTTOM OF HOLE				

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-06-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-22-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	11	SILTY CLAY				
		S-1:	SPT	5-6.5	12"	3-3-3
		S-2:	SPT	10-11.5	12"	2-2-3
11	21	FINE SILTY SAND				
		S-3: with trace clay	SPT	15-16.5	14"	2-1-1
		S-4:	SPT	18.5-20	6"	1-1-1
21	33	FINE TO MEDIUM SAND				
		S-5: with some clay and trace gravel	SPT	23.5-25	10"	2-1-2
		S-6: with coarse sand	SPT	28.5-30	8"	3-5-9
33	35	SHALE/CLAY				
		S-7:	SPT	33.5-35	2"	23 -
	35	BOTTOM OF HOLE				

WATER LEVEL OBSERVATIONS			NOTES	Piezometer Installed <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
DURING DRILLING	_____	FT.			Depth
AT COMPLETION	_____	FT.	39° 58.55N		
AFTER _____	HRS _____	FT.	093° 12.40W		
AFTER _____	HRS _____	FT.			
AFTER _____	HRS _____	FT.			



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-07-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-23-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	11	SILTY CLAY				
		S-1:	SPT	5-6.5	10"	3-3-3
		S-2:	SPT	10-11.5	18"	2-2-2
11	21	CLAYEY FINE SAND				
		S-3:	SPT	15-16.5	16"	1-1-1
		S-4:	SPT	18.5-20	8"	3-2-2
21	33	FINE TO COARSE SAND WITH TRACE GRAVEL				
		S-5: with some clay	SPT	23.5-25	10"	3-6-7
		S-6:	SPT	28.5-30	14"	5-12-14
33	33.5	SHALE/CLAY				
		S-7:	SPT	33.5-35	6"	Refusal
	33.5	BOTTOM OF HOLE				

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-08-03

Project LINN CO. PWSO #1

Job No. 03286

Date 10-27-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	11	SANDY CLAY				
		S-1:	SPT	5-6.5	14"	3-6-5
		S-2:	SPT	10-11.5	14"	3-3-1
11	37	FINE TO MEDIUM SAND				
		S-3: with some silt	SPT	15-16.5	14"	1-1-2
		S-4: with trace silt and gravel	SPT	18.5-20	12"	3-4-11
		S-5:	SPT	23.5-25	10"	2-3-5
		S-6: with coarse sand and gravel	SPT	28.5-30	4"	12-8-7
		S-7: with coarse sand and gravel	SPT	33.5-35	5"	9-3-3
37	50	SHALE/CLAY				
		S-8:	SPT	38.5-40	10"	3-7-8
		S-9:	SPT	43.5-45	8"	3-5-7
		S-10: with some sand	SPT	48.5-50	4"	3-5-7

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-09-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-28-03

Location Purdin, MO

Crew M. Cox, M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	17	CLAY				
		S-1:	SPT	5-6.5	12"	3-4-4
		S-2:	SPT	10-11.5	16"	2-2-2
		S-3: with fine sand	SPT	15-16.5	16"	1-2-2
17	10	FINE TO MEDIUM SAND				
		S-4: with some clay	SPT	18.5-20	14"	2-2-2
		S-5: with some clay	SPT	23.5-25	14"	1-2-3
		S-6:	SPT	28.5-30	14"	3-7-9
31	36	FINE TO COARSE SAND WITH GRAVEL				
		S-7:	SPT	33.5-35	16"	7-9-12
36	43	SHALE/CLAY				
		S-8:	SPT	38.5-40		Refusal
	43	BOTTOM OF HOLE				

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-10-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-29-03

Location Purdin, MO

Crew M. Cox & M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0	21	CLAY				
		S-1:	SPT	5-6.5	12"	4-4-4
		S-2: with fine sand	SPT	10-11.5	16"	3-3-4
		S-3: with fine sand	SPT	15-16.5	16"	3-4-3
		S-4: with Fine Sand and Wood	SPT	18.5-20	16"	4-3-2
21	36	FINE SAND				
		S-5: with traces of Wood	SPT	23.5-25	12"	3-3-3
		S-6: with some med sand and trace clay	SPT	28.5-30	8"	5-8-9
		S-7: with some med. to coarse sand & Gravel	SPT	33.5-35	6"	8-13-17
36	40	SHALE/CLAY				
		S-8:	SPT	38.5-40	14"	13-17-30

WATER LEVEL OBSERVATIONS			NOTES	Piezometer installed <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
DURING DRILLING	_____	FT.			Depth
AT COMPLETION	_____	FT.			39° 58.37N
AFTER _____ HRS	_____	FT.			093° 12.57W
AFTER _____ HRS	_____	FT.			
AFTER _____ HRS	_____	FT.			



Brotcke Well & Pump

FIELD BORING LOG

Boring No. TH-11-03

Project LINN CO. PWSD #1

Job No. 03286

Date 10-29-03

Location Purdin, MO

Crew M. Cox & M. Schaake

Drilling Method: HSA CFA Rotary Rock Coring Drilling Fluid Bent. Mud

DEPTH, FT.		DESCRIPTION	SAMPLE			SPT Blows N/6"
FROM	TO		TYPE	DEPTH, FT.	RECOVERY	
0		CLAY				
		S-1:	SPT	5-6.5	12"	2-2-3
		S-2:	SPT	10-11.5	14"	1-1-2
		S-3:	SPT	15-16.5	20"	0-1-1
		S-4: with some fine sand	SPT	18.5-20	16"	1-3-3
21	33	FINE TO MEDIUM SAND				
		S-5: with trace clay	SPT	23.5-25	10"	1-1-3
		S-6: with trace clay and gravel	SPT	28.5-30	8"	1-2-4
33	35	SHALE/CLAY				
		S-7:	SPT	33.5-35	10"	7-9-13
	35	BOTTOM OF HOLE				

<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p>
--	--------------

93.21667° W

WGS84 93.20000° W




City of Purdin
Linn County CPWSD No 1
Test Hole Summary

39.983333° N

39.983333° N


39.96667° N

39.96667° N



93.21667° W


WGS84 93.20000° W



C. Listing of Closed Systems

Inactive Sources Within Clusters						
Current Cluster	2015 Treated Water Demand	Type	System Name	County	Source	Year of Closure
GW-3	0.077	Ground Water	Livingston PWSD #1	Livingston	Failed wells (declining yield, likely due to iron/silt, drilled approx. 28 test wells with low yield); closed plant; now purchase water from Chillicothe	2005
GW-4	0.197	Ground Water	Chula	Livingston	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Livingston #2	1985
GW-6	0.013	Ground Water	Laredo	Grundy	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Linn-Livingston #3	2000
GW-6	0.028	Surface Water	Linneus	Linn	Inadequate lake (heavily silted, high organic matter, supplemented with Locust Creek when dry); closed plant; now purchase water from Linn-Livingston #3	2005
GW-6	0.02	Ground Water	Wheeling	Livingston	Well (declining yield, likely due to iron/silt); closed plant; now purchase water from Linn-Livingston #3	1980
GW-8	0.024	Surface Water	Mercer	Mercer	Inadequate lake (shallow and heavily silted); closed plant; now purchase water from Princeton	1990
OR-1	0.026	Surface Water	Downing	Schuyler	Inadequate lake (shallow and heavily silted); closed plant; now purchase water from Schuyler CPWSD #1	2000
OR-1	0.065	Surface Water	Lancaster	Schuyler	Inadequate lake (shallow and heavily silted); closed plant; now purchase water from Rathbun	2002
OR-1	0.24	Surface Water	Schuyler CPWSD #1	Schuyler	Inadequate lake and treatment facility; closed plant; now purchase water from Rathbun and Putnam PWSD #1	2002
OR-3	0.04	Surface Water	Jamesport	Daviess	Inadequate lake (shallow and heavily silted); closed plant; now purchase water from Livingston #4	2010
OR-3	0.001	Surface Water	Breckenridge	Caldwell	Inadequate lake; supplemented from Grand River well; closed inadequate treatment plant; now served water from Livingston #4	2014
SW-1	0.017	Ground Water	Browning	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1990
SW-1	0.122	Surface Water	Green City	Sullivan	Inadequate lakes to demand; single stage treatment facility became inadequate; closed plant; now purchase water from NCMRWC	2005
SW-1	0.007	Ground Water	Humphreys	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1990
SW-1	0.016	Ground Water	Newtown	Sullivan	Failed wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Sullivan PWSD #1	1995
SW-2	0.017	Surface Water	Bucklin	Linn	Inadequate lake (shallow and heavily silted); struggled with disinfection-by-products; closed plant; now purchase water from	2010
SW-2	N/A	Surface Water	Ethel	Macon	Inadequate lake (shallow and heavily silted); closed inadequate treatment plant; adsorbed by Chariton-Linn #3	1990
SW-2	0.031	Ground Water	Laclede	Linn	Failed shallow wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Brookfield	1980
SW-2	N/A	Surface Water	Lake Nehai Tonkayea	Chariton	Inadequate treatment plant; difficulty maintaining qualified operator; closed plant; adsorbed by Chariton-Linn #3	1990
SW-2	N/A	Ground Water	Mendon	Chariton	Failed shallow wells (declining yield, high in iron); closed plant; now purchase water from Chariton-Linn #3	2004
SW-2	N/A	Surface Water	New Cambria	Macon	Inadequate lake (shallow and heavily silted); closed inadequate treatment plant; adsorbed by Chariton-Linn #3	1990
SW-2	N/A	Ground Water	Rothville	Chariton	Failed shallow wells (declining yield, high in iron); closed plant; adsorbed by Chariton-Linn #3	1990
SW-2	N/A	Ground Water	Sumner	Chariton	Failed shallow wells with declining yield; closed plant; adsorbed by Chariton-Linn #3	2008
SW-4	0.021	Ground Water	Galt	Grundy	Failed shallow wells (declining yield, high in iron); closed plant; now purchase water from Grundy PWSD #1	1990
SW-4	0.028	Ground Water	Spickard	Grundy	Failed shallow wells (declining yield); closed plant; now purchase water from Linn-Livingston #3	1985
SW-5	0.079	Surface Water	La Plata	Macon	Inadequate lakes; closed inadequate treatment plant; now purchase water from Adair PWSD #1	2000
SW-5	0.026	Ground Water	Novinger	Adair	Failed shallow wells (declining yield); closed plant; now purchase water from Adair PWSD #1	2005
SW-6	0.02	Surface Water	Atlanta	Macon	Inadequate lake; struggled with disinfection-by-products; closed plant; now purchase water from Macon	1985
SW-6	0.024	Ground Water	Callao	Macon	Failed shallow wells (declining yield); closed plant; now purchase water from Macon PWSD #1	1990
SW-6	0.005	Ground Water	Elmer	Macon	Failed shallow wells (declining yield, likely due to iron/silt); closed plant; now purchase water from Macon PWSD #1	1985

D. Map of Closed Systems



Closed Drinking Water Treatment Facilities in the 10 County Region

This display is intended to show the closed and limited drinking water facilities in the 10 County Region as listed by Everett Baker in December 2015. The closed facilities are labeled with approximate closure dates, as recalled by Cary Sayre. Shape of icon indicates whether the plant is/was fed by ground or surface water.


ID	System Name	Yr. Closed
1	Atlanta	1985
2	Browning	1990
3	Bucklin	2010
4	Callao	1990
5	Chula	1985
6	Downing	2000
7	Elmer	1985
8	Ethel	1990
9	Galt	1990
10	Green City	2005
11	Humphreys	1990
12	La Plata	2000
13	Laclede	1980
14	Lake Nehai Tonkayea	1990
15	Lancaster	2002
16	Laredo	2000
17	Linneus	2005
18	Livingston Co. PWSD #1	2005

ID	System Name	Yr. Closed
19	Mendon	2004
20	Mercer	1990
21	New Cambria	1990
22	Newtown	1995
23	Novinger	2005
24	Rothville	1990
25	Schuyler Co. Cons. PWSD #1	2002
26	Spickard	1985
27	Sumner	2008
28	Wheeling	1980

Legend

- Study Region
- Inactive - Ground Water
- Inactive - Surface Water
- Streams/Rivers

E. Map of Treatment Facilities



F. Table of Closed Wells

Closed Wells in the 10 County Study Region
From MDNR Water Well Log Data Set

PWSSNAME	LOCALNAME	FED_TYPE	STATUS	DRILLDATE	ABAN	PLUG	MATERIAL	Form_ID	TOTDEPTH	STATICLEVE	YIELD	HEAD	DRAWDOWN
Novinger	Well #2, Old Well	C	Plugged	1977	0	1999	Unconsolidated	Alluvium	43	20	83	0	10
Chillicothe Municipal Utilities	Well #6 TEST HOLE	C	Abandoned	0	0	0	Unconsolidated	Glacial Deposits	135	0	0	158	0
Chillicothe Municipal Utilities	Well #7 TEST HOLE	C	Abandoned	0	0	0	Unconsolidated	Glacial Deposits	135	0	0	158	0
Keytesville	Well #2, T53N R18W Chariton (Sec.5)	C	Plugged	1959	0	2006	Unconsolidated	Alluvium	50	20	10	53	1
Keytesville	Well #3	C	Plugged	1986	0	2006	Unconsolidated	Alluvium	64	16	7	63	1
Keytesville	Well #1, T53N R18W Chariton (Sec.5)	C	Plugged	1936	0	2006	Unconsolidated	Alluvium	47	26	11	53	1
Lake Nehal Tonkayea	Chariton	NP	Inactive	1970	0	0	Unconsolidated	Alluvium	51	6	80	0	14
Linn Livingston Co. PWSD #3	Well #2, New Well	C	Inactive	1982	0	0	Unconsolidated	Glacial Deposits	138	60	235	0	16
Livingston Co. PWSD #1	Well #1	C	Inactive	1967	0	0	Unconsolidated	NUJL	0	24	104	0	22
Livingston Co. PWSD #1	Well #2 (WRC monitoring well)	C	Observation Well	1967	0	0	Unconsolidated	Glacial Deposits	79	7	100	0	60
Livingston Co. PWSD #1	Well #3	C	Inactive	1989	0	0	Unconsolidated	Glacial Deposits	83	27	114	0	0
Livingston Co. PWSD #2	Well #1	C	Inactive	1964	0	0	Unconsolidated	Glacial Deposits	181	91	94	0	68
Livingston Co. PWSD #2	Well #2	C	Inactive	1988	0	0	Unconsolidated	Glacial Deposits	139	53	240	0	110
Livingston County R I School	Well #1, School Wellhouse	NTNC	Inactive	0	0	0	Unconsolidated	Glacial Deposits	65	0	0	0	0
Mendon	Well #1	C	Observation Well	1955	0	0	Unconsolidated	Alluvium	52	0	0	0	0
Mendon	Well #2	C	Inactive	1955	0	0	Unconsolidated	Alluvium	54	0	0	0	0
Novinger	Well #1	C	Plugged	1958	1976	1986	Unconsolidated	Alluvium	44	8	210	125	20
Novinger	Well #3, New Well	C	Plugged	1982	0	1999	Unconsolidated	Alluvium	43	29	83	0	8
Princeton	Well #3	C	Inactive	1971	0	0	Unconsolidated	Alluvium	38	15	133	132	14
Princeton	Well #1	C	Plugged	1973	0	2009	Unconsolidated	Alluvium	38	15	90	0	8
Princeton	Well #1, Old	C	Plugged	0	1995	1995	Unconsolidated	NUJL	0	10	0	0	0
Princeton	Well #12	C	Plugged	0	1995	1995	Unconsolidated	NUJL	0	10	0	0	0
Princeton	Well #13	C	Plugged	0	1995	1995	Unconsolidated	NUJL	0	10	0	0	0
Princeton	Well #5	C	Plugged	0	0	2002	Unconsolidated	NUJL	0	0	0	0	0
Princeton	Well #7	C	Plugged	1978	0	2002	Unconsolidated	Alluvium	42	13	100	100	13
Princeton	Well #2B	C	Plugged	1968	0	2002	Unconsolidated	Alluvium	41	14	100	100	30
Sumner	Well #1	C	Inactive	0	0	0	Unconsolidated	Glacial Deposits	75	0	0	0	0
Sumner	Well #2	C	Inactive	0	0	0	Unconsolidated	Glacial Deposits	35	0	0	0	0

This data is from <http://drinkingwater.missouri.edu/gisdata/metadata/spwswell.html> collected on 8/30/2016 by A. Jones

G. Surface Water Supply Table

Surface Water Supply(s) Within Cluster											
Cluster	Lake/ Reservoir	Cluster Current Demand		Raw Water Yield: Without Pumping, With Sediment Loading		Excess Capacity (Cluster Yield-Cluster Normal Raw Demand) MGD	Lake Purpose (S=water supply, R=recreation, C=flood control) in order of importance	Year Dam Built	Surface Area (acre)	Total Volume (ac.-ft.)	Water Supply Volume (ac.-ft.)
		Normal Treated (MGD)	Normal Raw (MGD)	Source Yield Capacity (MGD)	Cluster Yield Capacity (MGD)						
SW-1	Elmwood Reservoir	1.622	1.629	0.800	0.940	-0.689	S, R	1972	194.8	2503.2	2416.5
SW-1	Milan Lake (Golf Course)			0.140			S, R	1940	41.0	555.21	500.27
SW-2	Brookfield Lake			0.180			S, R	1959	107.9	2070.3	1948.2
SW-2	Brookfield Reservoir	1.014	1.115	n/a	0.600	-0.515	S				
SW-2	Old Marceline Lake			n/a			S				
SW-2	Marceline Lake (New)			0.420			S, R	1980	172.8	1990	1812
SW-3	Unionville Reservoir	0.33	0.363	0.200	0.200	-0.163	S, R	1941	73.5	620	430
SW-4	Trenton Lower Reservoir	1.78	1.958	0.000	0.000	-1.958	S				
SW-4	Trenton Upper Reservoir			0.000			S				
SW-5	Forest Lake*	2.51	2.76	2.691	4.040	-0.120	R, S	1951	585.2	12500	10,380
SW-5	Hazel Creek Lake*	1.27	1.40	1.349			R, S	1982	501.7	8680	7,230
SW-6	Long Branch Lake	2.5	2.75	3.400	3.400	0.650	C, S, R				

* Normal Treated Demands were proportionally increased to account for the 0.35 MGD Kraft-Heinz expansion.


H. Stream Low Flow Table

Results from USGS Low Flow Equations* for Stream Intakes in 10 County Region

Cluster	Supplier	PWSSID	Intake	Inputs			Outputs		
				Drainage Area (MI ²)	Length (mi)	Stream Variable	7Q10 (MGD)	30Q10 (MGD)	60Q10 (MGD)
SW-1	NCMRWC	2021537	Locust Creek at Intake	217.63	44.08	0.745	0.264	0.568	0.921
SW-2	Marceline	2010497	Mussel Fork at Intake	146.7	55.6	0.695	0.100	0.229	0.284
SW-2	Brookfield	2010105	West Yellow Creek at intake	195.27	54.7	0.659	0.258	0.546	0.723
SW-4	Trenton	2010796	Thompson River at Intake	1722.3	155.46	0.714	6.268	8.673	12.949

* Computed Statistics at Streamgages, and Methods for Estimated Low-Flow Frequency Statistics and Development of Regional Regression Equations for Estimating Low Flow Frequency Statistics at Ungaged Locations in Missouri, USGS 2013

I. Treatment Plant Status



ID	System Name
GW-1	Keytesville
GW-2	Mo American - Brunswick
GW-3	Chillicothe - CMU
GW-4	Livingston Co. PWSD #2
GW-5	Linn Co. Cons. PWSD #1
GW-6	Linn-Livingston PWSD #3
GW-7	Meadville
GW-8	Princeton
GW-9	Salisbury

SW-1	NCMRWC
SW-2B	Brookfield
SW-2M	Marceline
SW-3	Unionville
SW-4	Trenton
SW-5	Kirksville
SW-6	Macon

Legend

- Study Region
- Adequate - Ground Water
- Inadequate - Ground Water
- ◆ Adequate - Surface Water
- ◆ Inadequate - Surface Water
- Streams/Rivers

J. Surface Water Cluster Production & Demand Table

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
SW-1	North Central Missouri Regional Water Commission					1.572		n/a
	Green City						100%	0.122
	Green Castle						100%	0.034
	Milan						100%	0.180
	Sullivan County PWSD #1						100%	0.274
	Browning						100%	0.017
	Humphreys						100%	0.007
	Newtown						100%	0.016
Premium Standard Farms (RAW Supply)							0.923	
SW-2	Brookfield					0.494		0.376
	Laclede						100%	0.031
	Chariton-Linn PWSD #3						25%	0.351
	Bucklin						100%	0.017
	Mendon						100%	0.018
	Chariton PSWD #2						35%	0.049
	Marceline					0.52		0.257
	Chariton-Linn PWSD #3						75%	0.351
	Bucklin						100%	0.017
	Mendon						100%	0.018
Chariton PSWD #2						35%	0.049	
SW-3	Unionville					0.33		0.150
	Putnam County PWSD #1						68%	0.207
	Lake Thunderhead HOA						100%	0.021
	Adair PWSD #1						0.75%	0.463
	Brashear						100%	0.014
	LaPlata						100%	0.079
	Novinger						100%	0.026
	Macon County PWSD #1						1%	0.014
	Callao						100%	0.024
	Clarence						100%	0.065
Elmer						100%	0.005	
SW-4	Trenton Municipal Utilities					1.718		1.477
	Grundy County PWSD #1						100%	0.241
	Galt						100%	0.021
	Spickard						100%	0.028
SW-5	Kirksville					3.432		2.969
	Adair PWSD #1						99%	0.463
	Brashear						100%	0.014
	LaPlata						100%	0.079
	Novinger						100%	0.026
	Macon County PWSD #1						1%	0.014
	Callao						100%	0.024
	Clarence						100%	0.065
Elmer						100%	0.005	
SW-6	Macon					2.5		
	Atlanta						100%	0.020
	Bevier						100%	0.056
	Macon County PWSD #1						81%	1.232
	Callao						100%	0.024
	Clarence						100%	0.065
Elmer						100%	0.005	

K. Groundwater Cluster Production & Demand Table

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
GW-1	Keytesville					0.0530		0.031
	Chariton PWSD #2						45%	0.049
GW-2	Mo American Brunswick					0.0841		0.057
	Chariton PWSD #2						55%	0.049
GW-3	Chillicothe Municipal Utilities					1.3		0.893
	Livingston Co. PWSD #1						100%	0.077
	Livingston Co. PWSD #2						49%	0.151
	Chula						100%	0.016
	Livingston Co. PWSD #3 East						100%	0.197
	Hale						100%	0.043
GW-4	Livingston Co. PWSD #2					0.0865	51%	0.151
	Chula						100%	0.016
GW-5	Linn Consolidated PWSD #1					0.085		0.085
GW-6	Linn-Livingston PWSD #3					0.168062		0.107
	Laredo						100%	0.013
	Linneus						100%	0.028
	Wheeling						100%	0.020
GW-7	Meadville					0.0335		0.034
GW-8	Princeton					0.137		0.080
	Mercer						100%	0.024
	Mercer County PWSD #1						5%	0.033
GW-9	Salisbury					0.1750		0.175

L. Out-of-Region Cluster Production & Demand Table

2015-2016 Cluster Average Daily Production and Demand (Treated Water Quantities)								
Source Cluster	Tier System					MGD Produced	% purchase from supplier	Total MGD Consumed
	1st	2nd	3rd	4th	5th			
OR-1	Rathbun					0.557		
	Lancaster						100%	0.065
	Glenwood						100%	0.133
	Mercer County PWSD #1						95%	0.160
	Putnam County PWSD #1						32%	0.207
	Lake Thunderhead HOA						100%	0.021
	Schuyler County CPWSD #1						100%	0.266
	Downing						100%	0.026
	Adair PWSD #1						0.25%	0.463
	Brashear						100%	0.014
	LaPlata						100%	0.079
	Novinger						100%	0.026
	Macon County PWSD #1						1%	0.014
	Callao						100%	0.024
	Clarence						100%	0.065
	Elmer						100%	0.005
OR-2	Clarence Cannon					0.278		
	Macon County PWSD #1						18%	1.523
	Callao						100%	0.024
	Clarence						100%	0.080
	Elmer						100%	0.005
OR-3	Livingston Co. PWSD 4					0.34		0.200
	Jamesport						100%	0.040
	Daviess PWSD #2						40%	0.100
	Jameson						100%	0.006
	Breckenridge						100%	0.001
	Hamilton						22%	0.050
	Caldwell County PWSD #2						100%	