Natural Resources Conservation Service

CONSERVATION PRACTICE STANDARD

WATER WELL

CODE 642

(no)

SLL REVIEW

DEFINITION

A hole drilled, dug, driven, bored, jetted, or otherwise constructed into an aquifer for agricultural water supply.

PURPOSE

This practice is used to accomplish one or more of the following purposes:

- Address the need for adequate livestock water quality and quantity
- Provide water for terrestrial wildlife
- Provide irrigation water

CONDITIONS WHERE PRACTICE APPLIES

This practice applies to all types of agricultural land where the quality and quantity of underground water is appropriate for the intended purpose.

This practice does not apply to—

- Wells constructed for domestic or public water supply.
- Monitoring wells, NRCS Conservation Practice Standard (CPS) Monitoring Well (Code 353), injection wells, temporary test wells, or piezometers.
- Pumps, surface supply lines, storage facilities, and related appurtenances.

CRITERIA

General Criteria Applicable to All Purposes

Law and regulations

The investigation, design, and installation of an agricultural water supply well must comply with all applicable governmental regulations, laws, permits, licenses, and registrations according to NRCS Title 450, General Manual (GM), Part 405, Subpart A, "Compliance with Laws and Regulations." Where applicable laws and regulations do not exist, follow industry standards, such as—

- A proposed well must comply with criteria in the current version of American Water Works Association (AWWA), A100-15, "Water Well Standard."
- A proposed irrigation well must comply with criteria in the current version of American Society of Agricultural and Biological Engineers (ASABE or ASAE) EP400.3, "Designing and Constructing Irrigation Wells."
- The well design and installation must comply with criteria in the current version of National Ground Water Association (NGWA) 01, "Water Well Construction Standard."

- The Ohio EPA has authority to adopt rules governing non-potable wells which include wells covered under this practice standard. Follow rules for siting, construction, grouting, development, and abandonment found in Ohio Administrative Code (OAC) 3745-9-01 through OAC 3745-9-10

Roles and responsibilities
Licensed water well driller is responsible for drilling and installing the water well, according to State regulations.

The landowner is responsible for obtaining all necessary permits, rights, or approvals according to NRCS 450-GM-405 and applicable laws, rules, and regulations.

The landowner and/or licensed contractor are responsible for locating all buried utilities in the project area, including drainage tiles and other structural measures.

The well installer and well owner are responsible for compliance with all applicable well siting, construction and abandonment requirements. (See Ohio Revised Code (ORC) Section 6111.42 and rules adopted in OAC Chapter 3745- 9).

Use only private contractors holding a valid registration with the Ohio department of health, in accordance with Chapter 3701-28-18 of the Ohio Administrative Code.

Any well or facility with multiple wells capable of withdrawing 100,000 or more gallons per day must be registered with the Ohio Department of Natural Resources, Division of Soil and Water Resources' Water Withdrawal Facilities Registration Program as required by Section 1521.16 of the ORC.

Site suitability
Use reliable local experience, and review all relevant geologic maps, reports, and well records maintained by State and Federal agencies to evaluate ground water quantity and quality. When local hydrogeologic data are limited or conditions are complex and uncertain, conduct onsite evaluation to provide professional recommendations regarding site suitability.

Locate the well according to the Occupational Safety and Health Administration (OSHA) Standard 1926.1408 (h), "Power line safety (up to 350 kV)–equipment operations" to comply with setback distances from overhead or underground utility lines or other safety hazards.

Locate the well away and upgradient from potential surface and subsurface contamination or pollution and areas subject to flooding, according to State regulations. In determining hydraulic gradient, consider both pumped and static water levels. See OAC 3745-9-04: Well Siting

Laterally locate the well to comply with applicable conservation practice standards and State-specific water well setback zones and prohibitions.

Clear the site of all trees, brush, and obstructions. Locate the drill rig, related equipment, and the well on relatively flat, reasonably dry, working surface for a safe and effective working environment.

Wellhead protection
Divert all surface runoff, precipitation, and drainage away from the wellhead. Compact, mound, and slope earth material away from the wellhead.

Protect the wellhead and associated appurtenances from contamination or damage by wildlife, livestock, farm machinery, vehicle parking, or other harmful human activity. See OAC 3745-9 and NRCS National Enginering Handbook (NEH) 210. Part 631 for further discussion.

Grouting and sealing the casing
When drilling into hard rock formations or physically stable geologic materials, install a minimum of 10 feet of casing.

SD REVIEW

For erodible, friable, or otherwise unstable materials, install watertight grouted casing.

Install a watertight seal in the annulus of all well casing. Acceptable sealants include mortar containing expansive hydraulic cement, bentonite-based grout, bentonite chips and pellets, sand-cement grout, neat cement, or concrete.

Use sealant, packers, or similar retaining device to isolate one or more aquifers or zones that produce poor ground water quality to prevent commingling or cross-contamination. Provide a similar positive seal to separate water-bearing zones where comingling is not desired.

For artesian wells (flowing and nonflowing), grout the casing and geologic units directly above and below the aquifer to retain its confining pressure.

When casing extends to the borehole bottom, install a watertight end cap or grout seal to prevent entry of geologic material. For designs requiring telescoped screen assemblies, install one or more sand-tight seals between the top of the telescoped screen assembly and the casing.

After well completion, provide a suitably threaded, flanged, welded cap, or compression seal to prevent entry of contaminants into the well.

See OAC 3745-9-07 and NRCS National Enginering Handbook (NEH) 210. Part 631 for further discussion

Casing materials
Acceptable materials for casing include steel, iron, stainless steel, copper alloys, plastic, fiberglass, concrete, or other material of equivalent strength, which have sufficient chemical resistance to the ground water for the design life of the well. See OAC 3745-9-05 for material specifications. To prevent galvanic corrosion, do not join dissimilar metals. Select a casing diameter to permit satisfactory installation and efficient operation of a submersible pump, if used. Typically, the casing diameter should be a minimum of 2 inches larger than the maximum outside diameter of the pump and pump column.

Select casing material that can withstand all anticipated static and dynamic pressures imposed on the casing while maintaining a watertight seal during installation, well development, and use throughout the design life of the well. When needed, mechanically support casing during installation to maintain joint integrity. Refer to NRCS National Engineering Handbook (NEH) (Title 210), Part 631, “Geology,” for guidance in determining proper differential head limitations for approved casing materials.

Screen and filter pack
Screen slot size and filter pack (artificial or natural) must conform to the characteristics listed in ASTM D5092, “Standard Practice for Design and Installation of Groundwater Monitoring Wells” and ASTM D6725, “Standard Practice for Direct Push Installation of Prepacked Screen Monitoring Wells in Unconsolidated Aquifers.” Use only manufactured well screen that consists of corrosion-resistant material.

Install a well screen and filter pack (artificial or natural) if any of the following conditions exist:

- Presence of a poorly graded, fine sand aquifer or heaving or caving sands;
- Presence of a highly variable aquifer, such as alternating sand and clay layers;
- Presence of a poorly cemented sandstone or other loosely compacted material;
- Requirement for maximum yield from a low-yielding aquifer;
- Hole drilled by reverse circulation.

Refer to ASTM D5092 and OAC 3745-9-05 for filter pack quality criteria and filter pack and well screen slot size compatibility with formation rock and soil.

Use a prepacked well screen for horizontal, vertical, or angled wells. Use an artificial filter pack if natural filter pack is unavailable.

SOIL REVIEW

Screen and filter pack installation
Position the well screen according to the depth of the water-bearing zone(s) below the ground surface and thickness of the water-bearing zone penetrated by the drill hole. Install a conventional filter pack from the bottom up and place in a manner that avoids segregation and bridging of particles. Install filter pack according to NRCS 210-NEH-631, OAC 3745-9-05, and ASTM D5092.

When bentonite seals are allowed, hydrate bentonite to facilitate expansion and fill voids. Hydrate bentonite according to manufacturer's recommendations.

For a screened well cased to the well bottom, install several extra feet of blank screen or casing at the bottom of the well to accommodate sediment that passes through the well screens and settles to the bottom of the well.

Access port
Install an access port with a minimum diameter of 0.5 inch to allow for unobstructed measurement of depth of the water surface, or for the installation of a pressure gage for measuring shut-in pressure of a flowing well.

Seal or cap access ports, pressure gages, and all other openings in the well cover to prevent entry of unwanted materials and to discourage tampering. A removable cap is acceptable for an access port.

Well development
After completing well construction, but before conducting well performance (aquifer) tests, develop the well to remove fines, drill cuttings, mud, drilling fluids, and additives. Well development is required for all water wells. Pump the well at approximately 120 percent of the anticipated normal production rate until water discharge is clear. Do not use the permanent pump to conduct any well development work. Refer to ASTM 5521 "Standard Guide for Development of Groundwater Monitoring Wells in Granular Aquifers" for well development procedure. See and follow OAC 3745-9-09: Well Development and Pumping Test

Water quality testing
If local water quality conditions are unknown or questionable, test the well water using parameters that pertain to well performance or the suitability of the water for its intended usage. Test well water according to NRCS CPS Groundwater Testing (Code 355).

Disinfection
Prior to chemical disinfection, remove foreign substances, such as grease, soil, sediment, joint dope, and scum from the well and near the wellhead. Clean all pump parts before placing them into the well. Disinfect the well using a chlorine compound at a concentration of a minimum 50 mg/L (50 ppm).

Well performance (aquifer) testing
Design the well so at maximum drawdown, the water surface does not drop to the top of the highest screen or pump intake. Wait no less than 24 hrs after well development is completed and the water level has stabilized, to conduct a pumping test for determining specific capacity and dynamic water levels. Refer to NRCS 210-NEH-631 and 210-NEH, Part 650, Chapter 12, Section 650.1205, "Wells" for guidance on conducting, recording, and analyzing pumping tests.

Discharge water a minimum of 300 feet from the well and in such a way that reduces erosion to the land surface and prevents potential artificial recharge during the test.

Take all measurements from the top of well casing.

CONSIDERATIONS

Consider the following when planning and designing a water well:

- Evaluate the potential capacity of a new well based upon the capacity of nearby wells to determine feasibility and storage needs to meet planned water supply needs

SDR REVIEW

- Evaluating the potential for adverse interference with existing nearby production wells when planning and designing the water well
- Health impacts of nitrates in groundwater used for livestock consumption. In areas of nitrogen fertilizer use, consider checking with the local Health Department for excess nitrogen levels in ground water
- Health impacts of ground water mineral content used for irrigation or animal watering. Minerals contained in ground water, such as selenium, sodium, sulfate, and others have the potential to negatively impact soil, plant and animal health
- For (aquifer) testing, consider the potential for ground water overdraft and the long-term, safe aquifer yield

PLANS AND SPECIFICATIONS

Develop plans and specifications that clearly describe requirements for applying the practice to achieve its intended purposes. If not already specified in the documentation required by the State regulatory authority, record the following information in the installation record:

- Location of water well by Global Positioning System (GPS) coordinates or in a sufficiently detailed narrative description to readily locate the well.
- Name of well owner.
- Type of casing material or schedule, and whether new or used.
- Height of casing extending aboveground surface.
- Static water level measured from top edge of casing or from ground surface.
- Well diameter, total well depth, and screened depth/interval.
- Notification of whether aquifer is artesian or non-artesian. If well is flowing artesian, provide flow rate and pressure.
- Screen slot size and filter gradation (if used).
- Drilling method and bore hole diameter.
- Well development methods used.
- Results of pump test, drawdown, pumping rate, specific capacity, and well efficiency.
- Driller's log for water-bearing and dry holes.
- If water quality was tested, record the parameters and test results, date of sampling, name of person who took sample, and name of laboratory that conducted tests.
- Schematic drawing of well construction showing well diameter and depth, casing and liner diameters, fill, bentonite, or grouting surface elevation, and top of well head elevation.
- Disinfection method and solution used, and date the well is disinfected.
- Required well capacity to meet resource concern
- Minimum setback distances
- As-built construction documents, maintenance records, and other available data for the well(s)
- Requirements for materials to be used
- Vegetative establishment requirements
- A note stating that well drilling contractors installing wells under this standard must be registered with the Ohio Department of Health as described in Chapter 3701-28-18 of the Ohio Administrative Code (OAC) "Registration and Bonding of Water Systems Contractors" and section 3701.344 of the Ohio Revised Code.
- A note stating that the well drilling contractor is required to file well log and drilling reports and well sealing reports with the Ohio Department of Natural Resources, Division of Geological Survey,conforming with Ohio Revised Code (ORC) 1521.05

PREVIEW

OPERATION AND MAINTENANCE

Prepare a site-specific plan for operation and maintenance of the water well. The owner is responsible for keeping and maintaining well construction records with the maintenance plan. The owner must ensure periodic inspection of the well for proper functioning and water quality.

Do not store or mix agricultural chemicals, such as fertilizers and pesticides, or rinse containers within a 100-foot radius of the wellhead.

Regular inspection must include conditions that affect well performance, based upon the well's intended use. As a minimum, these conditions include—

- Declines in discharge, static level, maximum pumping level, and pressure (for artesian wells) that are outside acceptable limits for the well design.
- Appearance of sediment that may damage the well, pump, or appurtenances.
- Changes in water quality including odor, color, taste, and chemistry.
- Presence of algae or iron bacteria.

For wells that have blank casing installed below the screen, periodically bail or flush the well to remove excessive, accumulated sediment.

In the maintenance record, include statements describing identified problems, corrective action taken and date, and specific capacity of well before and after corrective action. The owner must remedy unacceptable conditions in a timely manner.

In the event the well becomes unserviceable, it may be decommissioned according to NRCS Conservation Practice Standard Well Decommissioning (Code 351).

REFERENCES

American National Standards Institute National Groundwater Association (ANSI/NGWA-01-14). 2014. Water Well Construction.

American National Standards Institute/American Society of Agricultural Engineers (ANSI/ASAE). 2017. American National Standard EP400.3, Designing and Constructing Irrigation Wells.

American National Standards Institute/American Water Well Association (ANSI/AWWA). 2015. American National Standard, A100, Standard for Water Wells. American National Standard/American Water Well Association, Denver, CO. AWWA catalog no: 41100-2015, http://www.awwa.org.

ASTM D5521. 2018. Standard Guide for Development of Groundwater Monitoring Wells in Granular Aquifers. ASTM International, West Conshohocken, PA. DOI: 10.1520/D5521_D5521M-18, http://www.astm.org.

ASTM D5092. 2016. Standard Practice for Design and Installation of Groundwater Monitoring Wells. ASTM International, West Conshohocken, PA. DOI: 10.1520/D5092-D5092M-16, http://www.astm.org.

ASTM D6725. 2016.Standard Practice for Direct Push Installation of Prepacked Screen Monitoring Wells in Unconsolidated Aquifers. ASTM International, West Conshohocken, PA. DOI: 10.1520/D6725-D6725M-16, http://www.astm.org.

Occupational Safety and Health Administration. 2012. Power Line Safety (up to 350 kv) - equipment operations. Safety and Health Regulations for Construction Standard - 1926.1408, Subpart CC. Retrieved from https://www.osha.gov/laws-regs/regulations/standardnumber/1926/1926.1408.

USDA NRCS. 2010. National Engineering Handbook (Title 210), Part 631..
https://directives.sc.egov.usda.gov/

SD PREVIEW

USDA NRCS. 2012. National Engineering Handbook (Title 210), Part 651, Chapter 1,Laws, Regulations, Policy, and Water Quality Criteria. https://directives.sc.egov.usda.gov/

USDA NRCS. 2012. National Engineering Handbook (Title 210), Part 650, Chapter 12, Section 650.1203, Chapter 12, Wells. https://directives.sc.egov.usda.gov/

Ohio Department of Natural Resources, Division of Geological Survey (Groundwater resources), Water Well Logs : https://waterwells.ohiodnr.gov/search

Ohio Environmental Protection Agency, Division of Drinking and Ground Waters, Rules, OAC 3745-9: https://epa.ohio.gov/divisions-and-offices/drinking-and-ground-waters/regulations/effective-rules

Ohio Revised Code, Section 3701.344, “Rules for Private Water Systems” https://codes.ohio.gov/ohio-revised-code/section-3701.344[MM(-NLO5]

Ohio Water Resources Council, State Coordinating Committee On Ground Water, March 2015, Regulations and Technical Guidance for Sealing Unused Water Wells and Boreholes https://epa.ohio.gov/static/Portals/28/documents/wellsealguide-2015.pdf

SDL REVIEW